



NASA AMES DEVELOPMENT PLAN

FINAL PROGRAMMATIC


ENVIRONMENTAL IMPACT STATEMENT



APPENDIX C: INFRASTRUCTURE APPENDIX

NASA AMES RESEARCH CENTER

JULY 2002




DESIGN, COMMUNITY & ENVIRONMENT

NASA AMES DEVELOPMENT PLAN
FINAL PROGRAMMATIC
ENVIRONMENTAL IMPACT STATEMENT
APPENDIX C

NASA AMES RESEARCH CENTER

JULY 2002



MANAGED BY


DANIEL, MANN, JOHNSON & MENDENHALL

394 PACIFIC AVENUE, THIRD FLOOR

TEL: 415 986 1373

SAN FRANCISCO, CALIFORNIA 94111-1718

FAX: 415 986 4886



PREPARED BY

DESIGN, COMMUNITY & ENVIRONMENT

1600 SHATTUCK AVENUE, SUITE 222

TEL: 510 848 3815

BERKELEY, CALIFORNIA 94709

FAX: 510 848 4315

in association with
FEHR & PEERS ASSOCIATES, INC.
NELSON NYGAARD
ILLINGWORTH & RODKIN
JONES & STOKES
DR. LYNNE TRULIO
BRIAN KANGAS FOULK
BAY AREA ECONOMICS

TABLE OF CONTENTS

APPENDIX C1: POTABLE WATER DEMAND

APPENDIX C2: RECLAIMED WATER DEMAND

APPENDIX C3: SANITARY SEWER DEMAND - EASTERN/SUNNYVALE

APPENDIX C4: SANITARY SEWER DEMAND - WESTERN/MOUNTAIN VIEW

APPENDIX C5: STORM DRAIN DISCHARGE

APPENDIX C6: NATURAL GAS DEMAND

NASA AMES RESEARCH CENTER
NASA AMES DEVELOPMENT PLAN
FINAL PROGRAMMATIC ENVIRONMENTAL IMPACT STATEMENT
APPENDIX C: TABLE OF CONTENTS

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 1
WATER ANALYSIS
SUMMARY
POTABLE WATER DEMAND

Average Domestic Water Demand for Determining Required Emergency Storage
Average and Peak Domestic Water Demand for Determining Regional Impacts

Summary of Existing and Proposed Water Demand for Development Areas Covered by EIS

Existing flows were determined based on meter readings at NASA ARC. Proposed demands for the various alternates are based on the calculations shown on the spreadsheets on the following pages.

| Development Alternate | Standard Water Demands | | Reduced Water Demands | | Demand Reduction | |
|-----------------------|-------------------------------|------------------------------|-------------------------------|------------------------------|-------------------------------|------------------------------|
| | Annual Water Demand (gallons) | Peak Hour Water Demand (gpm) | Annual Water Demand (gallons) | Peak Hour Water Demand (gpm) | Annual Water Demand (gallons) | Peak Hour Water Demand (gpm) |
| Exist - indoor only | 131,300,000 | 1,000 | | | | |
| Existing - total | 237,800,000 | 2,570 | | | | |
| 1 - indoor only (a) | 140,200,000 | 1,070 | 128,300,000 | 980 | 11,800,000 | 90 |
| 1 - total (c) | 241,900,000 | 2,560 | 230,100,000 | 2,470 | | |
| 2 - indoor only | 296,800,000 | 2,260 | 206,700,000 | 1,570 | 90,100,000 | 690 |
| 2 - total (d) | 337,400,000 | 2,910 | 247,300,000 | 2,220 | | |
| 3 - indoor only | 254,100,000 | 1,930 | 179,100,000 | 1,360 | 75,000,000 | 570 |
| 3 - total (d) | 296,300,000 | 2,610 | 221,400,000 | 2,040 | | |
| 4 - indoor only | 343,100,000 | 2,610 | 236,000,000 | 1,790 | 107,100,000 | 810 |
| 4 - total (d) | 383,700,000 | 3,260 | 276,600,000 | 2,450 | | |
| 5 - indoor only (b) | 270,500,000 | 2,060 | 194,500,000 | 1,480 | 76,000,000 | 580 |
| 5 - total (d) | 312,700,000 | 2,740 | 236,800,000 | 2,160 | | |

Notes: (a) Baseline

(b) Preferred Alternative

(c) Total value for Alternate 1 includes Irrigation for Moffett Field Golf Course, Ames Campus, and portions of NRP and Eastside/Airfield that will continue to be irrigated with potable water.

(d) Total values for Alternates 2-5 include Irrigation for Ames Campus and portions of Eastside/Airfield that will continue to be irrigated with potable water.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 1
WATER ANALYSIS**

**TABLE 1.0
AVERAGE AND PEAK DOMESTIC WATER DEMAND - EXISTING**

Average Day Domestic Water Demand for Determining Required Emergency Storage
Annual Water Demand and Peak Hour Domestic Water Demand for Determining Regional Impacts

| Development Area \ Description | Area | Existing Water Demands | | | | |
|--|--------------|------------------------|--------------------------------|-------------------------------|--------------------------------|----------------------------------|
| | | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) (1) |
| NASA RESEARCH PARK | | | | | | |
| Existing Buildings | 1,577,269 sf | 0.128 gpd/sf | 201,302 | 73,525,516 | 140 | 559 |
| Subtotal - NRP | 1,577,269 sf | | 201,302 | 73,525,516 | 140 | 559 |
| EASTSIDE/AIRFIELD | | | | | | |
| Existing Buildings | 79,023 sf | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 |
| Hangars 2 & 3 | 780,613 sf | 0.020 gpd/sf | 15,612 | 5,702,378 | 11 | 43 |
| Subtotal - EastSide/Airfield | 859,636 sf | | 25,698 | 9,386,091 | 18 | 71 |
| AMES CAMPUS | | | | | | |
| Existing Buildings | 2,889,658 sf | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 |
| Subtotal - Ames Campus | 2,889,658 sf | | 132,536 | 48,408,762 | 92 | 368 |
| Total Indoor Demand - EIS | | | 359,536 | 131,320,369 | 250 | 999 |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 |
| California Air National Guard | 42 acre | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 |
| Total Indoor Demand - Non EIS | | | 160,920 | 58,776,000 | 112 | 447 |
| Total Indoor Demand - NASA ARC | | | 520,455 | 190,096,369 | 361 | 1446 |
| IRRIGATION | | | | | | |
| Not From Reclaimed | | | | | | |
| NASA Research Park | 199 acre | 463 gpd/acre | 92,137 | 33,653,039 | 2.72 | 541 |
| Eastside/Airfield | 10 acre | 463 gpd/acre | 4,630 | 1,691,108 | 2.72 | 27 |
| Ames Campus | 240 acre | 463 gpd/acre | 111,120 | 40,586,580 | 2.72 | 653 |
| Moffett Field Golf Course | 100 acre | 836 gpd/acre | 83,600 | 30,534,900 | 3.50 | 350 |
| Total Irrigation Demand - EIS | | | 291,487 | 106,465,627 | | 1571 |
| Orion Park Military Housing | 79 acre | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 |
| Berry Court Military Housing | 37 acre | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 |
| California Air National Guard | 42 acre | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 |
| Total Irrigation Demand - Non EIS | | | 73,154 | 26,719,499 | | 430 |
| Total Irrigation Demand-NASA ARC | | | 364,641 | 133,185,125 | | 2,001 |
| Total Water Demand - EIS | | | 651,023 | 237,785,996 | | 2,570 |
| Total Water Demand - NASA ARC | | | 885,096 | 323,281,494 | | 3,447 |

Notes: (1) Peak hour demand is four times the average day demand.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 1
WATER ANALYSIS - TABLE 1.1
AVERAGE AND PEAK DOMESTIC WATER DEMAND - ALTERNATE 1
Average Day Domestic Water Demand for Determining Required Emergency Storage
Annual Water Demand and Peak Hour Domestic Water Demand for Determining Regional Impacts

| Development Area \ Description | Area | Standard Water Demands | | | | | Reduced Water Demands | | | | | Demand Reduction | |
|--|--------------|------------------------|--------------------------------|-------------------------------|--------------------------------|----------------------------------|-----------------------|--------------------------------|-------------------------------|--------------------------------|----------------------------------|---|----------------------------------|
| | | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) (1) | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) (1) | Annual Water Demand Reduction (gallons) | Peak Hour Demand Reduction (gpm) |
| LAB | | | | | | | | | | | | | |
| Office/High Density R&D | 690,000 sf | 0.10 gpd/sf | 69,000 | 25,202,250 | 48 | 192 | 0.06 gpd/sf | 41,400 | 15,121,350 | 29 | 115 | 10,080,900 | 77 |
| Auditorium | 30,000 sf | 0.06 gpd/sf | 1,800 | 657,450 | 1 | 5 | 0.04 gpd/sf | 1,200 | 438,300 | 1 | 3 | 219,150 | 2 |
| Subtotal - Lab | 720,000 sf | | 70,800 | 25,859,700 | 49 | 197 | | 42,600 | 15,559,650 | 30 | 118 | 10,300,050 | 78 |
| NASA RESEARCH PARK | | | | | | | | | | | | | |
| Existing Buildings | 1,129,962 sf | 0.128 gpd/sf | 144,214 | 52,673,982 | 100 | 401 | 0.128 gpd/sf | 144,214 | 52,673,982 | 100 | 401 | 0 | 0 |
| Invisible Studios | 105,000 sf | 0.10 gpd/sf | 10,500 | 3,835,125 | 7 | 29 | 0.06 gpd/sf | 6,300 | 2,301,075 | 4 | 18 | 1,534,050 | 12 |
| Subtotal - NRP | 1,234,962 sf | | 154,714 | 56,509,107 | 107 | 430 | | 150,514 | 54,975,057 | 105 | 418 | 1,534,050 | 12 |
| Subtotal - Lab and NRP | 1,954,962 sf | | 225,514 | 82,368,807 | 157 | 626 | | 193,114 | 70,534,707 | 134 | 536 | 11,834,100 | 90 |
| EASTSIDE/AIRFIELD | | | | | | | | | | | | | |
| Existing Buildings | 79,023 sf | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 | 0 | 0 |
| Hangars 2 & 3 | 780,613 sf | 0.02 gpd/sf | 15,612 | 5,702,378 | 11 | 43 | 0.02 gpd/sf | 15,612 | 5,702,378 | 11 | 43 | 0 | 0 |
| Subtotal - EastSide/Airfield | 859,636 sf | | 25,698 | 9,386,091 | 18 | 71 | | 25,698 | 9,386,091 | 18 | 71 | 0 | 0 |
| AMES CAMPUS | | | | | | | | | | | | | |
| Existing Buildings | 2,889,658 sf | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 | 0 | 0 |
| Subtotal - Ames Campus | 2,889,658 sf | | 132,536 | 48,408,762 | 92 | 368 | | 132,536 | 48,408,762 | 92 | 368 | 0 | 0 |
| Total Indoor Demand - EIS | | | 383,747 | 140,163,660 | 266 | 1066 | | 351,347 | 128,329,560 | 244 | 976 | 11,834,100 | 90 |
| ORION PARK MILITARY HOUSING | | | | | | | | | | | | | |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 | 0 | 0 |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 | 0 | 0 |
| California Air National Guard | 42 acre | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 | 0 | 0 |
| Total Indoor Demand - Non EIS | | | 160,920 | 58,776,000 | 112 | 447 | | 160,920 | 58,776,000 | 112 | 447 | 0 | 0 |
| Total Indoor Demand - NASA ARC | | | 544,667 | 198,939,660 | 378 | 1513 | | 512,267 | 187,105,560 | 356 | 1423 | 11,834,100 | 90 |
| IRRIGATION | | | | | | | | | | | | | |
| Not From Reclaimed | | | | | | | | | | | | | |
| NASA Research Park | 171 acre | 463 gpd/acre | 79,173 | 28,917,938 | 2.72 | 465 | 463 gpd/acre | 79,173 | 28,917,938 | 2.72 | 465 | | |
| Eastside/Airfield | 10 acre | 463 gpd/acre | 4,630 | 1,691,108 | 2.72 | 27 | 463 gpd/acre | 4,630 | 1,691,108 | 2.72 | 27 | | |
| Ames Campus | 240 acre | 463 gpd/acre | 111,120 | 40,586,580 | 2.72 | 653 | 463 gpd/acre | 111,120 | 40,586,580 | 2.72 | 653 | | |
| Moffett Field Golf Course | 100 acre | 836 gpd/acre | 83,600 | 30,534,900 | 3.50 | 350 | 836 gpd/acre | 83,600 | 30,534,900 | 3.50 | 350 | | |
| Total Irrigation Demand - EIS | | | 278,523 | 101,730,526 | | 1495 | | 278,523 | 101,730,526 | | 1495 | | |
| ORION PARK MILITARY HOUSING | | | | | | | | | | | | | |
| Orion Park Military Housing | 79 acre | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 | | |
| Berry Court Military Housing | 37 acre | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 | | |
| California Air National Guard | 42 acre | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 | | |
| Total Irrigation Demand - Non EIS | | | 73,154 | 26,719,499 | | 430 | | 73,154 | 26,719,499 | | 430 | | |
| Total Irrigation Demand-NASA ARC | | | 351,677 | 128,450,024 | | 1925 | | 351,677 | 128,450,024 | | 1925 | | |
| Total Water Demand - EIS | | | 662,270 | 241,894,186 | | 2561 | | 629,870 | 230,060,086 | | 2471 | | |
| Total Water Demand - NASA ARC | | | 896,344 | 327,389,684 | | 3438 | | 863,944 | 315,555,584 | | 3348 | | |

Notes:
(1) Peak hour demand is four times the average day demand.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 1
WATER ANALYSIS - TABLE 1.2**

AVERAGE AND PEAK DOMESTIC WATER DEMAND - ALTERNATE 2

Average Day Domestic Water Demand for Determining Required Emergency Storage
Annual Water Demand and Peak Hour Domestic Water Demand for Determining Regional Impacts

| Development Area \ Description | Area | Standard Water Demands | | | | | Reduced Water Demands | | | | | Demand Reduction | | | |
|--|--------------|------------------------------|--------------------------------|-------------------------------|--------------------------------|------------------------------|-----------------------|--------------------------------|-------------------------------|--------------------------------|------------------------------|---|----------------------------------|------|-----|
| | | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) | Annual Water Demand Reduction (gallons) | Peak Hour Demand Reduction (gpm) | | |
| LAB | | | | | | | | | | | | | | | |
| Office/High Density R&D | 690,000 sf | 0.10 gpd/sf | 69,000 | 25,202,250 | 48 | 192 | 0.06 gpd/sf | 41,400 | 15,121,350 | 29 | 115 | 10,080,900 | 77 | | |
| Auditorium | 30,000 sf | 0.06 gpd/sf | 1,800 | 657,450 | 1 | 5 | 0.04 gpd/sf | 1,200 | 438,300 | 1 | 3 | 219,150 | 2 | | |
| Subtotal - Lab | 720,000 sf | | 70,800 | 25,859,700 | 49 | 197 | | 42,600 | 15,559,650 | 30 | 118 | 10,300,050 | 78 | | |
| NASA RESEARCH PARK | | | | | | | | | | | | | | | |
| Existing Buildings | 112,990 sf | 0.128 gpd/sf | 14,421 | 5,267,109 | 10 | 40 | 0.128 gpd/sf | 14,421 | 5,267,109 | 10 | 40 | 0 | 0 | | |
| Office / R&D / University | 1,447,010 sf | 0.10 gpd/sf | 144,701 | 52,852,040 | 100 | 402 | 0.06 gpd/sf | 86,821 | 31,711,224 | 60 | 241 | 21,140,816 | 161 | | |
| Museum / Conference Center | 660,000 sf | 0.05 gpd/sf | 33,000 | 12,053,250 | 23 | 92 | 0.03 gpd/sf | 19,800 | 7,231,950 | 14 | 55 | 4,821,300 | 37 | | |
| Part Time Housing (1 unit/800 sf) | 150,000 sf | 200.00 gpd/unit | 37,500 | 13,696,875 | 26 | 104 | 137.00 gpd/unit | 25,688 | 9,382,359 | 18 | 71 | 4,314,516 | 33 | | |
| Family Housing (1 unit/1,200 sf) | 360,000 sf | 250.00 gpd/unit | 75,000 | 27,393,750 | 52 | 208 | 172.00 gpd/unit | 51,600 | 18,846,900 | 36 | 143 | 8,546,850 | 65 | | |
| Retail | 50,000 sf | 0.06 gpd/sf | 3,000 | 1,095,750 | 2 | 8 | 0.04 gpd/sf | 2,000 | 730,500 | 1 | 6 | 365,250 | 3 | | |
| Subtotal - NRP | 2,780,000 sf | | 307,622 | 112,358,774 | 214 | 855 | | 200,329 | 73,170,043 | 139 | 556 | 39,188,732 | 298 | | |
| Subtotal - Lab and NRP | 3,500,000 sf | | 378,422 | 138,218,474 | 263 | 1051 | | 242,929 | 88,729,693 | 169 | 675 | 49,488,782 | 376 | | |
| BAY VIEW | | | | | | | | | | | | | | | |
| Office / R&D / University | 1,000,000 sf | 0.10 gpd/sf | 100,000 | 36,525,000 | 69 | 278 | 0.06 gpd/sf | 60,000 | 21,915,000 | 42 | 167 | 14,610,000 | 111 | | |
| Family Housing (1 unit/1,200 sf) | 300,000 sf | 250.00 gpd/unit | 62,500 | 22,828,125 | 43 | 174 | 172.00 gpd/unit | 43,000 | 15,705,750 | 30 | 119 | 7,122,375 | 54 | | |
| Subtotal - Bay View | 1,300,000 sf | | 162,500 | 59,353,125 | 113 | 451 | | 103,000 | 37,620,750 | 72 | 286 | 21,732,375 | 165 | | |
| EASTSIDE/AIRFIELD | | | | | | | | | | | | | | | |
| Existing Buildings | 79,023 sf | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 | 0 | 0 | | |
| Office / R&D / Industrial | 1,250,613 sf | 0.10 gpd/sf | 125,061 | 45,678,640 | 87 | 347 | 0.06 gpd/sf | 75,037 | 27,407,184 | 52 | 208 | 18,271,456 | 139 | | |
| Conference Center | 80,000 sf | 0.05 gpd/sf | 4,000 | 1,461,000 | 3 | 11 | 0.03 gpd/sf | 2,400 | 876,600 | 2 | 7 | 584,400 | 4 | | |
| Subtotal - EastSide/Airfield | 1,409,636 sf | | 139,147 | 50,823,353 | 97 | 387 | | 87,522 | 31,967,497 | 61 | 243 | 18,855,856 | 143 | | |
| AMES CAMPUS | | | | | | | | | | | | | | | |
| Existing Buildings | 2,889,658 sf | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 | 0 | 0 | | |
| Subtotal - Ames Campus | 2,889,658 sf | | 132,536 | 48,408,762 | 92 | 368 | | 132,536 | 48,408,762 | 92 | 368 | 0 | 0 | | |
| Total Indoor Demand - EIS | | | 812,604 | 296,803,714 | 564 | 2257 | | 565,987 | 206,726,702 | 393 | 1572 | 90,077,013 | 685 | | |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 | 0 | 0 | | |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 | 0 | 0 | | |
| California Air National Guard | 42 acre | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 | 0 | 0 | | |
| Total Indoor Demand - Non EIS | | | 160,920 | 58,776,000 | 112 | 447 | | 160,920 | 58,776,000 | 112 | 447 | 0 | 0 | | |
| Total Indoor Demand - NASA ARC | | | 973,524 | 355,579,714 | 676 | 2704 | | 726,907 | 265,502,701 | 505 | 2019 | 90,077,013 | 685 | | |
| IRRIGATION | | | | | | | | | | | | | | | |
| Not From Reclaimed | | | | | | | | | | | | | | | |
| Ames Campus | 240 acre | Average Unit Demand gpd/acre | 463 gpd/acre | 111,120 | 40,586,580 | Peak Unit Demand gpm/acre | 2.72 | 653 | Average Unit Demand gpd/acre | 463 gpd/acre | 111,120 | 40,586,580 | Peak Unit Demand gpm/acre | 2.72 | 653 |
| Total Irrigation Demand - EIS | | | 111,120 | 40,586,580 | | 653 | | 111,120 | 40,586,580 | | 653 | | 653 | | |
| Orion Park Military Housing | 79 acre | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 | | | | |
| Berry Court Military Housing | 37 acre | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 | | | | |
| California Air National Guard | 42 acre | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 | | | | |
| Total Irrigation Demand - Non EIS | | | 73,154 | 26,719,499 | | 430 | | 73,154 | 26,719,499 | | 430 | | 430 | | |
| Total Irrigation Demand-NASA ARC | | | 184,274 | 67,306,079 | | 1083 | | 184,274 | 67,306,079 | | 1083 | | 1083 | | |
| Total Water Demand - EIS | | | 923,724 | 337,390,294 | | 2910 | | 677,107 | 247,313,282 | | 2225 | | 2225 | | |
| Total Water Demand - NASA ARC | | | 1,157,798 | 422,885,792 | | 3787 | | 911,181 | 332,808,780 | | 3102 | | 3102 | | |

Notes:

(1) Peak hour demand is four times the average day demand.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 1
WATER ANALYSIS - TABLE 1.3**

AVERAGE AND PEAK DOMESTIC WATER DEMAND - ALTERNATE 3
Average Day Domestic Water Demand for Determining Required Emergency Storage
Annual Water Demand and Peak Hour Domestic Water Demand for Determining Regional Impacts

| Development Area \ Description | Area | Standard Water Demands | | | | | Reduced Water Demands | | | | | Demand Reduction | |
|--|--------------|------------------------|--------------------------------|-------------------------------|--------------------------------|------------------------------|-----------------------|--------------------------------|-------------------------------|--------------------------------|------------------------------|---|----------------------------------|
| | | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) | Annual Water Demand Reduction (gallons) | Peak Hour Demand Reduction (gpm) |
| LAB | | | | | | | | | | | | | |
| Office/High Density R&D | 690,000 sf | 0.10 gpd/sf | 69,000 | 25,202,250 | 48 | 192 | 0.06 gpd/sf | 41,400 | 15,121,350 | 29 | 115 | 10,080,900 | 77 |
| Auditorium | 30,000 sf | 0.06 gpd/sf | 1,800 | 657,450 | 1 | 5 | 0.04 gpd/sf | 1,200 | 438,300 | 1 | 3 | 219,150 | 2 |
| Subtotal - Lab | 720,000 sf | | 70,800 | 25,859,700 | 49 | 197 | | 42,600 | 15,559,650 | 30 | 118 | 10,300,050 | 78 |
| NASA RESEARCH PARK | | | | | | | | | | | | | |
| Existing Buildings | 112,990 sf | 0.128 gpd/sf | 14,421 | 5,267,109 | 10 | 40 | 0.128 gpd/sf | 14,421 | 5,267,109 | 10 | 40 | 0 | 0 |
| Office / R&D / University | 2,372,010 sf | 0.10 gpd/sf | 237,201 | 86,637,665 | 165 | 659 | 0.06 gpd/sf | 142,321 | 51,982,599 | 99 | 395 | 34,655,066 | 264 |
| Museum / Conference Center | 710,000 sf | 0.05 gpd/sf | 35,500 | 12,966,375 | 25 | 99 | 0.03 gpd/sf | 21,300 | 7,779,825 | 15 | 59 | 5,186,550 | 39 |
| Part Time Housing (1 unit/800 sf) | 150,000 sf | 200.00 gpd/unit | 37,500 | 13,696,875 | 26 | 104 | 137.00 gpd/unit | 25,688 | 9,382,359 | 18 | 71 | 4,314,516 | 33 |
| Family Housing (1 unit/1,200 sf) | 360,000 sf | 250.00 gpd/unit | 75,000 | 27,393,750 | 52 | 208 | 172.00 gpd/unit | 51,600 | 18,846,900 | 36 | 143 | 8,546,850 | 65 |
| Retail | 75,000 sf | 0.06 gpd/sf | 4,500 | 1,643,625 | 3 | 13 | 0.04 gpd/sf | 3,000 | 1,095,750 | 2 | 8 | 547,875 | 4 |
| Subtotal - NRP | 3,780,000 sf | | 404,122 | 147,605,399 | 281 | 1123 | | 258,329 | 94,354,543 | 179 | 718 | 53,250,857 | 405 |
| Subtotal - Lab and NRP | 4,500,000 sf | | 474,922 | 173,465,099 | 330 | 1319 | | 300,929 | 109,914,193 | 209 | 836 | 63,550,907 | 483 |
| EASTSIDE/AIRFIELD | | | | | | | | | | | | | |
| Existing Buildings | 79,023 sf | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 | 0 | 0 |
| Office / R&D / Industrial | 780,613 sf | 0.10 gpd/sf | 78,061 | 28,511,890 | 54 | 217 | 0.06 gpd/sf | 46,837 | 17,107,134 | 33 | 130 | 11,404,756 | 87 |
| Subtotal - EastSide/Airfield | 859,636 sf | | 88,147 | 32,195,603 | 61 | 245 | | 56,922 | 20,790,847 | 40 | 158 | 11,404,756 | 87 |
| AMES CAMPUS | | | | | | | | | | | | | |
| Existing Buildings | 2,889,658 sf | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 | 0 | 0 |
| Subtotal - Ames Campus | 2,889,658 sf | | 132,536 | 48,408,762 | 92 | 368 | | 132,536 | 48,408,762 | 92 | 368 | 0 | 0 |
| Total Indoor Demand - EIS | | | 695,604 | 254,069,464 | 483 | 1932 | | 490,387 | 179,113,802 | 341 | 1362 | 74,955,663 | 570 |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 | 0 | 0 |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 | 0 | 0 |
| California Air National Guard | 42 acre | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 | 0 | 0 |
| Total Indoor Demand - Non EIS | | | 160,920 | 58,776,000 | 112 | 447 | | 160,920 | 58,776,000 | 112 | 447 | 0 | 0 |
| Total Indoor Demand - NASA ARC | | | 856,524 | 312,845,464 | 595 | 2379 | | 651,307 | 237,889,801 | 452 | 1809 | 74,955,663 | 570 |
| IRRIGATION | | | | | | | | | | | | | |
| Not From Reclaimed | | | | | | | | | | | | | |
| Eastside/Airfield | 10 acre | 463 gpd/acre | 4,630 | 1,691,108 | 2.72 | 27 | 463 gpd/acre | 4,630 | 1,691,108 | 2.72 | 27 | | |
| Ames Campus | 240 acre | 463 gpd/acre | 111,120 | 40,586,580 | 2.72 | 653 | 463 gpd/acre | 111,120 | 40,586,580 | 2.72 | 653 | | |
| Total Irrigation Demand - EIS | | | 115,750 | 42,277,688 | | 680 | | 115,750 | 42,277,688 | | 680 | | |
| Orion Park Military Housing | 79 acre | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 | | |
| Berry Court Military Housing | 37 acre | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 | | |
| California Air National Guard | 42 acre | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 | | |
| Total Irrigation Demand - Non EIS | | | 73,154 | 26,719,499 | | 430 | | 73,154 | 26,719,499 | | 430 | | |
| Total Irrigation Demand-NASA ARC | | | 188,904 | 68,997,186 | | 1110 | | 188,904 | 68,997,186 | | 1110 | | |
| Total Water Demand - EIS | | | 811,354 | 296,347,152 | | 2612 | | 606,137 | 221,391,489 | | 2042 | | |
| Total Water Demand - NASA ARC | | | 1,045,428 | 381,842,650 | | 3489 | | 840,211 | 306,886,987 | | 2919 | | |

Notes:
(1) Peak hour demand is four times the average day demand.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 1
WATER ANALYSIS - TABLE 1.4**

AVERAGE AND PEAK DOMESTIC WATER DEMAND - ALTERNATE 4

Average Day Domestic Water Demand for Determining Required Emergency Storage
Annual Water Demand and Peak Hour Domestic Water Demand for Determining Regional Impacts

| Development Area \ Description | Area | Standard Water Demands | | | | | Reduced Water Demands | | | | | Demand Reduction | | | |
|--|--------------|------------------------------|--------------------------------|-------------------------------|--------------------------------|------------------------------|-----------------------|--------------------------------|-------------------------------|--------------------------------|------------------------------|---|----------------------------------|------|-----|
| | | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) | Annual Water Demand Reduction (gallons) | Peak Hour Demand Reduction (gpm) | | |
| LAB | | | | | | | | | | | | | | | |
| Office/High Density R&D | 690,000 sf | 0.10 gpd/sf | 69,000 | 25,202,250 | 48 | 192 | 0.06 gpd/sf | 41,400 | 15,121,350 | 29 | 115 | 10,080,900 | 77 | | |
| Auditorium | 30,000 sf | 0.06 gpd/sf | 1,800 | 657,450 | 1 | 5 | 0.04 gpd/sf | 1,200 | 438,300 | 1 | 3 | 219,150 | 2 | | |
| Subtotal - Lab | 720,000 sf | | 70,800 | 25,859,700 | 49 | 197 | | 42,600 | 15,559,650 | 30 | 118 | 10,300,050 | 78 | | |
| NASA RESEARCH PARK | | | | | | | | | | | | | | | |
| Existing Buildings | 112,990 sf | 0.128 gpd/sf | 14,421 | 5,267,109 | 10 | 40 | 0.128 gpd/sf | 14,421 | 5,267,109 | 10 | 40 | 0 | 0 | | |
| Office / R&D / University | 1,107,010 sf | 0.10 gpd/sf | 110,701 | 40,433,540 | 77 | 308 | 0.06 gpd/sf | 66,421 | 24,260,124 | 46 | 185 | 16,173,416 | 123 | | |
| Museum / Conference Center | 645,000 sf | 0.05 gpd/sf | 32,250 | 11,779,313 | 22 | 90 | 0.03 gpd/sf | 19,350 | 7,067,588 | 13 | 54 | 4,711,725 | 36 | | |
| Part Time Housing (1 unit/800 sf) | 115,000 sf | 200.00 gpd/unit | 28,750 | 10,500,938 | 20 | 80 | 137.00 gpd/unit | 19,694 | 7,193,142 | 14 | 55 | 3,307,795 | 25 | | |
| Family Housing (1 unit/1,200 sf) | 265,000 sf | 250.00 gpd/unit | 55,208 | 20,164,844 | 38 | 153 | 172.00 gpd/unit | 37,983 | 13,873,413 | 26 | 106 | 6,291,431 | 48 | | |
| Retail | 35,000 sf | 0.06 gpd/sf | 2,100 | 767,025 | 1 | 6 | 0.04 gpd/sf | 1,400 | 511,350 | 1 | 4 | 255,675 | 2 | | |
| Subtotal - NRP | 2,280,000 sf | | 243,430 | 88,912,768 | 169 | 676 | | 159,268 | 58,172,726 | 111 | 442 | 30,740,043 | 234 | | |
| Subtotal - Lab and NRP | 3,000,000 sf | | 314,230 | 114,772,468 | 218 | 873 | | 201,868 | 73,732,376 | 140 | 561 | 41,040,093 | 312 | | |
| BAY VIEW | | | | | | | | | | | | | | | |
| Office / R&D / University | 2,040,000 sf | 0.10 gpd/sf | 204,000 | 74,511,000 | 142 | 567 | 0.06 gpd/sf | 122,400 | 44,706,600 | 85 | 340 | 29,804,400 | 227 | | |
| Family Housing (1 unit/1,200 sf) | 660,000 sf | 250.00 gpd/unit | 137,500 | 50,221,875 | 95 | 382 | 172.00 gpd/unit | 94,600 | 34,552,650 | 66 | 263 | 15,669,225 | 119 | | |
| Subtotal - Bay View | 2,700,000 sf | | 341,500 | 124,732,875 | 237 | 949 | | 217,000 | 79,259,250 | 151 | 603 | 45,473,625 | 346 | | |
| EASTSIDE/AIRFIELD | | | | | | | | | | | | | | | |
| Existing Buildings | 79,023 sf | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 | 0 | 0 | | |
| Office / R&D / Industrial | 1,370,613 sf | 0.10 gpd/sf | 137,061 | 50,061,640 | 95 | 381 | 0.06 gpd/sf | 82,237 | 30,036,984 | 57 | 228 | 20,024,656 | 152 | | |
| Conference Center | 80,000 sf | 0.05 gpd/sf | 4,000 | 1,461,000 | 3 | 11 | 0.03 gpd/sf | 2,400 | 876,600 | 2 | 7 | 584,400 | 4 | | |
| Subtotal - EastSide/Airfield | 1,529,636 sf | | 151,147 | 55,206,353 | 105 | 420 | | 94,722 | 34,597,297 | 66 | 263 | 20,609,056 | 157 | | |
| AMES CAMPUS | | | | | | | | | | | | | | | |
| Existing Buildings | 2,889,658 sf | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 | 0 | 0 | | |
| Subtotal - Ames Campus | 2,889,658 sf | | 132,536 | 48,408,762 | 92 | 368 | | 132,536 | 48,408,762 | 92 | 368 | 0 | 0 | | |
| Total Indoor Demand - EIS | | | 939,413 | 343,120,458 | 652 | 2609 | | 646,126 | 235,997,684 | 449 | 1795 | 107,122,774 | 815 | | |
| Non EIS | | | | | | | | | | | | | | | |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 | 0 | 0 | | |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 | 0 | 0 | | |
| California Air National Guard | 42 acre | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 | 0 | 0 | | |
| Total Indoor Demand - Non EIS | | | 160,920 | 58,776,000 | 112 | 447 | | 160,920 | 58,776,000 | 112 | 447 | 0 | 0 | | |
| Total Indoor Demand - NASA ARC | | | 1,100,333 | 401,896,458 | 764 | 3056 | | 807,046 | 294,773,684 | 560 | 2242 | 107,122,774 | 815 | | |
| IRRIGATION | | | | | | | | | | | | | | | |
| Not From Reclaimed | | | | | | | | | | | | | | | |
| Ames Campus | 240 acre | Average Unit Demand gpd/acre | 463 gpd/acre | 111,120 | 40,586,580 | Peak Unit Demand gpm/acre | 2.72 | 653 | Average Unit Demand gpd/acre | 463 gpd/acre | 111,120 | 40,586,580 | Peak Unit Demand gpm/acre | 2.72 | 653 |
| Total Irrigation Demand - EIS | | | 111,120 | 40,586,580 | | 653 | | 111,120 | 40,586,580 | | 653 | | | | |
| Non EIS | | | | | | | | | | | | | | | |
| Orion Park Military Housing | 79 acre | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 | | | | |
| Berry Court Military Housing | 37 acre | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 | | | | |
| California Air National Guard | 42 acre | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 | | | | |
| Total Irrigation Demand - Non EIS | | | 73,154 | 26,719,499 | | 430 | | 73,154 | 26,719,499 | | 430 | | | | |
| Total Irrigation Demand-NASA ARC | | | 184,274 | 67,306,079 | | 1083 | | 184,274 | 67,306,079 | | 1083 | | | | |
| Total Water Demand - EIS | | | 1,050,533 | 383,707,038 | | 3262 | | 757,246 | 276,584,264 | | 2448 | | | | |
| Total Water Demand - NASA ARC | | | 1,284,607 | 469,202,536 | | 4139 | | 991,320 | 362,079,763 | | 3324 | | | | |

Notes:

(1) Peak hour demand is four times the average day demand.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 1
WATER ANALYSIS - TABLE 1.5**

AVERAGE AND PEAK DOMESTIC WATER DEMAND - ALTERNATE 5
Average Day Domestic Water Demand for Determining Required Emergency Storage
Annual Water Demand and Peak Hour Domestic Water Demand for Determining Regional Impacts

| Development Area \ Description | Area | Standard Water Demands | | | | | Reduced Water Demands | | | | | Demand Reduction | |
|--|--------------|------------------------------|--------------------------------|-------------------------------|--------------------------------|------------------------------|------------------------------|--------------------------------|-------------------------------|--------------------------------|------------------------------|---|----------------------------------|
| | | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) | Unit Water Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) | Average Day Water Demand (gpm) | Peak Hour Water Demand (gpm) | Annual Water Demand Reduction (gallons) | Peak Hour Demand Reduction (gpm) |
| LAB | | | | | | | | | | | | | |
| Office/High Density R&D | 690,000 sf | 0.10 gpd/sf | 69,000 | 25,202,250 | 48 | 192 | 0.06 gpd/sf | 41,400 | 15,121,350 | 29 | 115 | 10,080,900 | 77 |
| Auditorium | 30,000 sf | 0.06 gpd/sf | 1,800 | 657,450 | 1 | 5 | 0.04 gpd/sf | 1,200 | 438,300 | 1 | 3 | 219,150 | 2 |
| Subtotal - Lab | 720,000 sf | | 70,800 | 25,859,700 | 49 | 197 | | 42,600 | 15,559,650 | 30 | 118 | 10,300,050 | 78 |
| NASA RESEARCH PARK | | | | | | | | | | | | | |
| Existing Buildings | 54,355 sf | 0.128 gpd/sf | 6,937 | 2,533,797 | 5 | 19 | 0.128 gpd/sf | 6,937 | 2,533,797 | 5 | 19 | 0 | 0 |
| Office / R&D / University | 1,521,645 sf | 0.10 gpd/sf | 152,165 | 55,578,084 | 106 | 423 | 0.06 gpd/sf | 91,299 | 33,346,850 | 63 | 254 | 22,231,233 | 169 |
| Museum / Conference Center | 895,000 sf | 0.05 gpd/sf | 44,750 | 16,344,938 | 31 | 124 | 0.03 gpd/sf | 26,850 | 9,806,963 | 19 | 75 | 6,537,975 | 50 |
| Part Time Housing (1 unit/800 sf) | 232,000 sf | 200.00 gpd/unit | 58,000 | 21,184,500 | 40 | 161 | 137.00 gpd/unit | 39,730 | 14,511,383 | 28 | 110 | 6,673,118 | 51 |
| Retail | 77,000 sf | 0.06 gpd/sf | 4,620 | 1,687,455 | 3 | 13 | 0.04 gpd/sf | 3,080 | 1,124,970 | 2 | 9 | 562,485 | 4 |
| Subtotal - NRP | 2,780,000 sf | | 266,472 | 97,328,773 | 185 | 740 | | 167,896 | 61,323,962 | 117 | 466 | 36,004,811 | 274 |
| Subtotal - Lab and NRP | 3,500,000 sf | | 337,272 | 123,188,473 | 234 | 937 | | 210,496 | 76,883,612 | 146 | 585 | 46,304,861 | 352 |
| BAY VIEW | | | | | | | | | | | | | |
| Child Care | 25,000 sf | 0.07 gpd/sf | 1,750 | 639,188 | 1 | 5 | 0.04 gpd/sf | 1,000 | 365,250 | 1 | 3 | 273,938 | 2 |
| Retail | 75,000 sf | 0.06 gpd/sf | 4,500 | 1,643,625 | 3 | 13 | 0.04 gpd/sf | 3,000 | 1,095,750 | 2 | 8 | 547,875 | 4 |
| Family Housing (1 unit/1,200 sf) | 900,000 sf | 250.00 gpd/unit | 187,500 | 68,484,375 | 130 | 521 | 172.00 gpd/unit | 129,000 | 47,117,250 | 90 | 358 | 21,367,125 | 163 |
| Subtotal - Bay View | 1,000,000 sf | | 193,750 | 70,767,188 | 135 | 538 | | 133,000 | 48,578,250 | 92 | 369 | 22,188,938 | 169 |
| EASTSIDE/AIRFIELD | | | | | | | | | | | | | |
| Existing Buildings | 79,023 sf | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 | 0.128 gpd/sf | 10,085 | 3,683,713 | 7 | 28 | 0 | 0 |
| Hangars 2 & 3 | 780,613 sf | 0.02 gpd/sf | 15,612 | 5,702,378 | 11 | 43 | 0.02 gpd/sf | 15,612 | 5,702,378 | 11 | 43 | 0 | 0 |
| Low Density R&D / Industrial | 12,000 sf | 0.10 gpd/sf | 1,200 | 438,300 | 1 | 3 | 0.06 gpd/sf | 720 | 262,980 | 1 | 2 | 175,320 | 1 |
| Subtotal - EastSide/Airfield | 871,636 sf | | 26,898 | 9,824,391 | 19 | 75 | | 26,418 | 9,649,071 | 18 | 73 | 175,320 | 1 |
| AMES CAMPUS | | | | | | | | | | | | | |
| Existing Buildings | 2,889,658 sf | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 | 0.046 gpd/sf | 132,536 | 48,408,762 | 92 | 368 | 0 | 0 |
| Office/High Density R&D | 500,000 sf | 0.10 gpd/sf | 50,000 | 18,262,500 | 35 | 139 | 0.06 gpd/sf | 30,000 | 10,957,500 | 21 | 83 | 7,305,000 | 56 |
| Subtotal - Ames Campus | 3,389,658 sf | | 182,536 | 66,671,262 | 127 | 507 | | 162,536 | 59,366,262 | 113 | 451 | 7,305,000 | 56 |
| Total Indoor Demand - EIS | | | 740,455 | 270,451,314 | 514 | 2057 | | 532,450 | 194,477,195 | 370 | 1479 | 75,974,118 | 578 |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 | 225.00 gpd/unit | 97,875 | 35,748,844 | 68 | 272 | 0 | 0 |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 | 225.00 gpd/unit | 24,750 | 9,039,938 | 17 | 69 | 0 | 0 |
| California Air National Guard | 42 acre | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 | 912 gpd/acre | 38,295 | 13,987,218 | 27 | 106 | 0 | 0 |
| Total Indoor Demand - Non EIS | | | 160,920 | 58,776,000 | 112 | 447 | | 160,920 | 58,776,000 | 112 | 447 | 0 | 0 |
| Total Indoor Demand - NASA ARC | | | 901,375 | 329,227,313 | 626 | 2504 | | 693,369 | 253,253,195 | 482 | 1926 | 75,974,118 | 578 |
| IRRIGATION | | | | | | | | | | | | | |
| Not From Reclaimed | | Average Unit Demand gpd/acre | | | Peak Unit Demand gpm/acre | | Average Unit Demand gpd/acre | | | Peak Unit Demand gpm/acre | | | |
| Eastside/Airfield | 10 acre | 463 gpd/acre | 4,630 | 1,691,108 | 2.72 | 27 | 463 gpd/acre | 4,630 | 1,691,108 | 2.72 | 27 | | |
| Ames Campus | 240 acre | 463 gpd/acre | 111,120 | 40,586,580 | 2.72 | 653 | 463 gpd/acre | 111,120 | 40,586,580 | 2.72 | 653 | | |
| Total Irrigation Demand - EIS | | | 115,750 | 42,277,688 | | 680 | | 115,750 | 42,277,688 | | 680 | | |
| Orion Park Military Housing | 79 acre | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 | 463 gpd/acre | 36,577 | 13,359,749 | 2.72 | 215 | | |
| Berry Court Military Housing | 37 acre | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 | 463 gpd/acre | 17,131 | 6,257,098 | 2.72 | 101 | | |
| California Air National Guard | 42 acre | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 | 463 gpd/acre | 19,446 | 7,102,652 | 2.72 | 114 | | |
| Total Irrigation Demand - Non EIS | | | 73,154 | 26,719,499 | | 430 | | 73,154 | 26,719,499 | | 430 | | |
| Total Irrigation Demand-NASA ARC | | | 188,904 | 68,997,186 | | 1110 | | 188,904 | 68,997,186 | | 1110 | | |
| Total Water Demand - EIS | | | 856,205 | 312,729,001 | | 2737 | | 648,200 | 236,754,883 | | 2159 | | |
| Total Water Demand - NASA ARC | | | 1,090,279 | 398,224,499 | | 3614 | | 882,273 | 322,250,381 | | 3036 | | |

Notes:
(1) Peak hour demand is four times the average day demand.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 1
WATER ANALYSIS**

**TABLE 1.6
AVERAGE WATER DEMAND - PENDING PROJECTS**

Annual Water Demand for Determining Regional Impacts

| TABLE 1.6 A - SUNNYVALE | | | | |
|---|----------------------|-----------------|--------------------------------|-------------------------------|
| Development Area \ Description | *Area | Unit Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) |
| Office/High Density R&D | 6,172,060 sf | 0.10 gpd/sf | 617,206 | 225,434,492 |
| Moffett Park | 28,600,000 sf | 0.10 gpd/sf | 2,860,000 | 1,044,615,000 |
| Retail | 562,397 sf | 0.10 gpd/sf | 56,240 | 20,541,550 |
| Hotel/Apartment (820 units @ 1,000 sf/unit) | 820,000 sf | 165.00 gpd/unit | 135,300 | 49,418,325 |
| Condo/Townhomes/Homes (316 units @ 1,200 sf/unit) | 379,200 sf | 180.00 gpd/unit | 56,880 | 20,775,420 |
| Child Care | 15,000 sf | 0.05 gpd/sf | 750 | 273,938 |
| Total Pending Projects in Sunnyvale | 36,548,657 sf | | 3,726,376 | 1,361,058,724 |

| TABLE 1.6 B - MOUNTAIN VIEW | | | | |
|--|---------------------|-----------------|--------------------------------|-------------------------------|
| Development Area \ Description | **Area | Unit Demand | Average Day Water Demand (gpd) | Annual Water Demand (gallons) |
| Office/High Density R&D | 2,201,000 sf | 0.10 gpd/sf | 220,100 | 80,391,525 |
| Retail | 8,820 sf | 0.10 gpd/sf | 882 | 322,151 |
| Condo/Multi-family (275 units @ 1,200 sf/unit) | 330,000 sf | 180.00 gpd/unit | 49,500 | 18,079,875 |
| Total Pending Projects in Mountain View | 2,539,820 sf | | 270,482 | 98,793,551 |

| | | | | |
|---|--|--|------------------|----------------------|
| Total Demand from Pending Projects | | | 3,996,858 | 1,459,852,275 |
|---|--|--|------------------|----------------------|

* Square footages based on September 2001 development update from Sunnyvale Planning Department.

**Square footages based on memorandum from Linda Forsberg, Deputy City Manager, dated September 17, 2000.

A P P E N D I X C 2

RECLAIMED WATER DEMAND



**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 2
RECLAIMED WATER / IRRIGATION ANALYSIS
SUMMARY SHEET
ANNUAL AND PEAK IRRIGATION DEMAND**

**Peak Irrigation Demand
(gpm)**

| Development Area \ Description | EXISTING * | ALTERNATE 1 | ALTERNATE 2 | ALTERNATE 3 | ALTERNATE 4 | ALTERNATE 5 |
|--------------------------------|------------|-------------|-------------|-------------|-------------|-------------|
| NASA RESEARCH PARK | 540 | 80 | 540 | 540 | 540 | 540 |
| AMES CAMPUS | 650 | 0 | 0 | 0 | 0 | 0 |
| EASTSIDE/AIRFIELD | 30 | 0 | 240 | 0 | 240 | 0 |
| BAY VIEW | 0 | 0 | 260 | 0 | 260 | 260 |
| GOLF COURSE | 350 | 0 | 350 | 350 | 350 | 350 |
| Subtotal for EIS | 1,570 | 80 | 1,390 | 890 | 1,390 | 1,150 |
| Berry Court Military Housing | 100 | 100 | 100 | 100 | 100 | 100 |
| Orion Park Military Housing | 210 | 210 | 210 | 210 | 210 | 210 |
| California Air National Guard | 110 | 110 | 110 | 110 | 110 | 110 |
| Subtotal - outside EIS | 420 | 420 | 420 | 420 | 420 | 420 |
| Total for NASA ARC | 1,990 | 500 | 1,810 | 1,310 | 1,810 | 1,570 |

* NOTE: EXISTING IRRIGATION DEMAND IS *NOT* FROM RECLAIMED WATER

**Annual Irrigation Demand
(gal)**

| Development Area \ Description | EXISTING * | ALTERNATE 1 | ALTERNATE 2 | ALTERNATE 3 | ALTERNATE 4 | ALTERNATE 5 |
|--------------------------------|-------------|-------------|-------------|-------------|-------------|-------------|
| NASA RESEARCH PARK | 33,600,000 | 4,700,000 | 33,600,000 | 33,600,000 | 33,600,000 | 33,600,000 |
| AMES CAMPUS | 40,600,000 | 0 | 0 | 0 | 0 | 0 |
| EASTSIDE/AIRFIELD | 1,700,000 | 0 | 15,000,000 | 0 | 15,000,000 | 0 |
| BAY VIEW | 0 | 0 | 16,100,000 | 0 | 16,100,000 | 16,100,000 |
| GOLF COURSE | 30,500,000 | 0 | 30,500,000 | 30,500,000 | 30,500,000 | 30,500,000 |
| Subtotal for EIS | 106,400,000 | 4,700,000 | 95,200,000 | 64,100,000 | 95,200,000 | 80,200,000 |
| Berry Court Military Housing | 6,300,000 | 6,300,000 | 6,300,000 | 6,300,000 | 6,300,000 | 6,300,000 |
| Orion Park Military Housing | 13,400,000 | 13,400,000 | 13,400,000 | 13,400,000 | 13,400,000 | 13,400,000 |
| California Air National Guard | 7,100,000 | 7,100,000 | 7,100,000 | 7,100,000 | 7,100,000 | 7,100,000 |
| Subtotal - outside EIS | 26,800,000 | 26,800,000 | 26,800,000 | 26,800,000 | 26,800,000 | 26,800,000 |
| Total for NASA ARC | 133,200,000 | 31,500,000 | 122,000,000 | 90,900,000 | 122,000,000 | 107,000,000 |

* NOTE: EXISTING IRRIGATION DEMAND IS *NOT* FROM RECLAIMED WATER

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 2
RECLAIMED WATER / IRRIGATION ANALYSIS
TABLE 2.0
EXISTING - NOT FROM RECLAIMED WATER
AVERAGE AND PEAK IRRIGATION FLOWS

| TABLE 2.0 | | Gross | Average | Annual | Gross | Peak |
|--------------------------------|-----------|--------------|------------|-------------|--------------|-------------|
| Development Area \ Description | Gross | Average Unit | Irrigation | Irrigation | Peak Unit | Irrigation |
| | Land Area | Irrigation | Demand | Demand | Irrigation | Demand |
| | | Demand | (gpd) | (gal) | Demand | (gpm) |
| LAB | 28 acres | 463 gpd/acre | 12,964 | 4,731,860 | 2.7 gpm/acre | 76 |
| NASA RESEARCH PARK | 171 acres | 463 gpd/acre | 79,173 | 28,898,145 | 2.7 gpm/acre | 465 |
| NRP Total | 199 acres | 463 gpd/acre | 92,137 | 33,630,005 | 2.7 gpm/acre | 541 |
| AMES CAMPUS | 240 acres | 463 gpd/acre | 111,120 | 40,558,800 | 2.7 gpm/acre | 653 |
| EASTSIDE/AIRFIELD * | 10 acres | 463 gpd/acre | 4,630 | 1,689,950 | 2.7 gpm/acre | 27 |
| BAY VIEW | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| GOLF COURSE | 100 acres | 836 gpd/acre | 83,600 | 30,514,000 | 3.5 gpm/acre | 350 |
| Subtotal for EIS | 549 | | 291,487 | 106,392,755 | | 1571 |
| Berry Court Military Housing | 37 acres | 463 gpd/acre | 17,131 | 6,252,815 | 2.7 gpm/acre | 101 |
| Orion Park Military Housing | 79 acres | 463 gpd/acre | 36,577 | 13,350,605 | 2.7 gpm/acre | 215 |
| California Air National Guard | 42 acres | 463 gpd/acre | 19,446 | 7,097,790 | 2.7 gpm/acre | 114 |
| Subtotal - outside EIS | 158 | | 73,154 | 26,701,210 | | 430 |
| Total for NASA ARC | 707 | | 364,641 | 133,093,965 | | 2001 |

* Total area for Eastside/Airfield is 89 acres. Roughly 10 acres is developed under existing conditions.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 2
RECLAIMED WATER / IRRIGATION ANALYSIS
TABLE 2.1
BASELINE - ALTERNATE 1
AVERAGE AND PEAK IRRIGATION FLOWS

| TABLE 2.1 | | Gross | Average | Annual | Gross | Peak |
|--------------------------------|-----------|--------------|------------|------------|--------------|------------|
| Development Area \ Description | Gross | Average Unit | Irrigation | Irrigation | Peak Unit | Irrigation |
| | Land Area | Irrigation | Demand | Demand | Irrigation | Demand |
| | | Demand | (gpd) | (gal) | Demand | (gpm) |
| LAB | 28 acres | 463 gpd/acre | 12,964 | 4,731,860 | 2.7 gpm/acre | 76 |
| NASA RESEARCH PARK # | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| NRP Total | 28 acres | 463 gpd/acre | 12,964 | 4,731,860 | 2.7 gpm/acre | 76 |
| AMES CAMPUS # | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| EASTSIDE/AIRFIELD * | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| BAY VIEW | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| GOLF COURSE | 0 acres | 836 gpd/acre | 0 | 0 | 3.5 gpm/acre | 0 |
| Subtotal for EIS | 28 | | 12,964 | 4,731,860 | | 76 |
| Berry Court Military Housing | 37 acres | 463 gpd/acre | 17,131 | 6,252,815 | 2.7 gpm/acre | 101 |
| Orion Park Military Housing | 79 acres | 463 gpd/acre | 36,577 | 13,350,605 | 2.7 gpm/acre | 215 |
| California Air National Guard | 42 acres | 463 gpd/acre | 19,446 | 7,097,790 | 2.7 gpm/acre | 114 |
| Subtotal - outside EIS | 158 | | 73,154 | 26,701,210 | | 430 |
| Total for NASA ARC | 186 | | 86,118 | 31,433,070 | | 506 |

Existing NRP and AMES CAMPUS will not be retrofitted to use reclaimed water for irrigation.

* Eastside/Airfield will not be retrofitted to use reclaimed water for irrigation.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 2
RECLAIMED WATER / IRRIGATION ANALYSIS
TABLE 2.2
PROPOSED - ALTERNATE 2
AVERAGE AND PEAK IRRIGATION FLOWS

| TABLE 2.2 | | Gross | Average | Annual | Gross | Peak |
|--------------------------------|-----------|--------------|------------|-------------|--------------|-------------|
| Development Area \ Description | Gross | Average Unit | Irrigation | Irrigation | Peak Unit | Irrigation |
| | Land Area | Irrigation | Demand | Demand | Irrigation | Demand |
| | | Demand | (gpd) | (gal) | Demand | (gpm) |
| LAB | 28 acres | 463 gpd/acre | 12,964 | 4,731,860 | 2.7 gpm/acre | 76 |
| NASA RESEARCH PARK | 171 acres | 463 gpd/acre | 79,173 | 28,898,145 | 2.7 gpm/acre | 465 |
| NRP Total | 199 acres | 463 gpd/acre | 92,137 | 33,630,005 | 2.7 gpm/acre | 541 |
| AMES CAMPUS # | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| EASTSIDE/AIRFIELD | 89 acres | 463 gpd/acre | 41,207 | 15,040,555 | 2.7 gpm/acre | 242 |
| BAY VIEW | 95 acres | 463 gpd/acre | 43,985 | 16,054,525 | 2.7 gpm/acre | 258 |
| GOLF COURSE | 100 acres | 836 gpd/acre | 83,600 | 30,514,000 | 3.5 gpm/acre | 350 |
| Subtotal for EIS | 483 | | 260,929 | 95,239,085 | | 1392 |
| Berry Court Military Housing | 37 acres | 463 gpd/acre | 17,131 | 6,252,815 | 2.7 gpm/acre | 101 |
| Orion Park Military Housing | 79 acres | 463 gpd/acre | 36,577 | 13,350,605 | 2.7 gpm/acre | 215 |
| California Air National Guard | 42 acres | 463 gpd/acre | 19,446 | 7,097,790 | 2.7 gpm/acre | 114 |
| Subtotal - outside EIS | 158 | | 73,154 | 26,701,210 | | 430 |
| Total for NASA ARC | 641 | | 334,083 | 121,940,295 | | 1822 |

AMES CAMPUS will not be retrofitted to use reclaimed water for irrigation.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 2
RECLAIMED WATER / IRRIGATION ANALYSIS
TABLE 2.3
PROPOSED - ALTERNATE 3
AVERAGE AND PEAK IRRIGATION FLOWS**

| TABLE 2.3 | | Gross | Average | Annual | Gross | Peak |
|--------------------------------|-----------|--------------|------------|------------|--------------|-------------|
| Development Area \ Description | Gross | Average Unit | Irrigation | Irrigation | Peak Unit | Irrigation |
| | Land Area | Irrigation | Demand | Demand | Irrigation | Demand |
| | | Demand | (gpd) | (gal) | Demand | (gpm) |
| LAB | 28 acres | 463 gpd/acre | 12,964 | 4,731,860 | 2.7 gpm/acre | 76 |
| NASA RESEARCH PARK | 171 acres | 463 gpd/acre | 79,173 | 28,898,145 | 2.7 gpm/acre | 465 |
| NRP Total | 199 acres | 463 gpd/acre | 92,137 | 33,630,005 | 2.7 gpm/acre | 541 |
| AMES CAMPUS # | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| EASTSIDE/AIRFIELD | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| BAY VIEW | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| GOLF COURSE | 100 acres | 836 gpd/acre | 83,600 | 30,514,000 | 3.5 gpm/acre | 350 |
| Subtotal for EIS | 299 | | 175,737 | 64,144,005 | | 891 |
| Berry Court Military Housing | 37 acres | 463 gpd/acre | 17,131 | 6,252,815 | 2.7 gpm/acre | 101 |
| Orion Park Military Housing | 79 acres | 463 gpd/acre | 36,577 | 13,350,605 | 2.7 gpm/acre | 215 |
| California Air National Guard | 42 acres | 463 gpd/acre | 19,446 | 7,097,790 | 2.7 gpm/acre | 114 |
| Subtotal - outside EIS | 158 | | 73,154 | 26,701,210 | | 430 |
| Total for NASA ARC | 457 | | 248,891 | 90,845,215 | | 1321 |

AMES CAMPUS will not be retrofitted to use reclaimed water for irrigation.

* Eastside/Airfield will not be retrofitted to use reclaimed water for irrigation.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 2
RECLAIMED WATER / IRRIGATION ANALYSIS
TABLE 2.4
PROPOSED - ALTERNATE 4
AVERAGE AND PEAK IRRIGATION FLOWS**

| TABLE 2.4 | | Gross | Average | Annual | Gross | Peak |
|--------------------------------|-----------|--------------|------------|-------------|--------------|-------------|
| Development Area \ Description | Gross | Average Unit | Irrigation | Irrigation | Peak Unit | Irrigation |
| | Land Area | Irrigation | Demand | Demand | Irrigation | Demand |
| | | Demand | (gpd) | (gal) | Demand | (gpm) |
| LAB | 28 acres | 463 gpd/acre | 12,964 | 4,731,860 | 2.7 gpm/acre | 76 |
| NASA RESEARCH PARK | 171 acres | 463 gpd/acre | 79,173 | 28,898,145 | 2.7 gpm/acre | 465 |
| NRP Total | 199 acres | 463 gpd/acre | 92,137 | 33,630,005 | 2.7 gpm/acre | 541 |
| AMES CAMPUS # | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| EASTSIDE/AIRFIELD | 89 acres | 463 gpd/acre | 41,207 | 15,040,555 | 2.7 gpm/acre | 242 |
| BAY VIEW | 95 acres | 463 gpd/acre | 43,985 | 16,054,525 | 2.7 gpm/acre | 258 |
| GOLF COURSE | 100 acres | 836 gpd/acre | 83,600 | 30,514,000 | 3.5 gpm/acre | 350 |
| Subtotal for EIS | 483 | | 260,929 | 95,239,085 | | 1392 |
| Berry Court Military Housing | 37 acres | 463 gpd/acre | 17,131 | 6,252,815 | 2.7 gpm/acre | 101 |
| Orion Park Military Housing | 79 acres | 463 gpd/acre | 36,577 | 13,350,605 | 2.7 gpm/acre | 215 |
| California Air National Guard | 42 acres | 463 gpd/acre | 19,446 | 7,097,790 | 2.7 gpm/acre | 114 |
| Subtotal - outside EIS | 158 | | 73,154 | 26,701,210 | | 430 |
| Total for NASA ARC | 641 | | 334,083 | 121,940,295 | | 1822 |

AMES CAMPUS will not be retrofitted to use reclaimed water for irrigation.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 2
RECLAIMED WATER / IRRIGATION ANALYSIS
TABLE 2.5
PROPOSED - ALTERNATE 5
AVERAGE AND PEAK IRRIGATION FLOWS

| TABLE 2.5 | | Gross | Average | Annual | Gross | Peak |
|--------------------------------|-----------|--------------|------------|-------------|--------------|-------------|
| Development Area \ Description | Gross | Average Unit | Irrigation | Irrigation | Peak Unit | Irrigation |
| | Land Area | Irrigation | Demand | Demand | Irrigation | Demand |
| | | Demand | (gpd) | (gal) | Demand | (gpm) |
| LAB | 28 acres | 463 gpd/acre | 12,964 | 4,731,860 | 2.7 gpm/acre | 76 |
| NASA RESEARCH PARK | 171 acres | 463 gpd/acre | 79,173 | 28,898,145 | 2.7 gpm/acre | 465 |
| NRP Total | 199 acres | 463 gpd/acre | 92,137 | 33,630,005 | 2.7 gpm/acre | 541 |
| AMES CAMPUS # | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| EASTSIDE/AIRFIELD | 0 acres | 463 gpd/acre | 0 | 0 | 2.7 gpm/acre | 0 |
| BAY VIEW | 95 acres | 463 gpd/acre | 43,985 | 16,054,525 | 2.7 gpm/acre | 258 |
| GOLF COURSE | 100 acres | 836 gpd/acre | 83,600 | 30,514,000 | 3.5 gpm/acre | 350 |
| Subtotal for EIS | 394 | | 219,722 | 80,198,530 | | 1150 |
| Berry Court Military Housing | 37 acres | 463 gpd/acre | 17,131 | 6,252,815 | 2.7 gpm/acre | 101 |
| Orion Park Military Housing | 79 acres | 463 gpd/acre | 36,577 | 13,350,605 | 2.7 gpm/acre | 215 |
| California Air National Guard | 42 acres | 463 gpd/acre | 19,446 | 7,097,790 | 2.7 gpm/acre | 114 |
| Subtotal - outside EIS | 158 | | 73,154 | 26,701,210 | | 430 |
| Total for NASA ARC | 552 | | 292,876 | 106,899,740 | | 1579 |

AMES CAMPUS will not be retrofitted to use reclaimed water for irrigation.

* Total area for Eastside/Airfield is 89 acres. Roughly 15 acres is developed under Alternative 5.

A P P E N D I X C 3

SANITARY SEWER DEMAND -
EASTERN/SUNNYVALE



**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 3
SANITARY SEWER ANALYSIS
SUMMARY**

SANITARY SEWER DEMAND - EASTERN / SUNNYVALE SYSTEM

Area Flowing to Sunnyvale

Almost 1400 acres of NASA ARC currently discharge sanitary sewer to the system operated by the City of Sunnyvale. The contributing areas are listed below.

| Project Areas Flowing to Sunnyvale | Area |
|---|------------|
| NASA Research Park - including Shenandoah Plaza | 213 acres |
| Southern & Eastern Portion of Ames Campus | 64 acres |
| Berry Court Military Housing | 37 acres |
| California Air National Guard | 110 acres |
| Eastside/Airfield | 952 acres |
| Total to Sunnyvale System | 1376 acres |

Note: The areas listed in the table to the left represent actual land areas, including sparsely developed areas that contribute negligible sewage flow. Areas listed in spreadsheets on the following pages represent the developed areas of the project site and are for calculation

Summary of Existing and Proposed Sanitary Sewer flows

Existing flows were determined based on meter readings at the pump station located at the northeast corner of the project site, which pumps into a force main that discharges into a City of Sunnyvale sewer main. Proposed flows for the various alternates are based on the calculations shown on the spreadsheets on the following pages.

| Development Alternate | Conveyance System Peak Wet Weather Sewer Flow (gpm) (1) | Treatment Plant Peak Wet Weather Sewer Flow (MGD) (2) |
|-----------------------|--|--|
| Existing | 1318 gpm | 0.86 MGD |
| 1 - Baseline | 1319 gpm | 0.87 MGD |
| 2 | 1576 gpm | 1.07 MGD |
| 3 | 1640 gpm | 1.08 MGD |
| 4 | 1498 gpm | 1.02 MGD |
| 5 - Preferred | 1336 gpm | 0.88 MGD |

- NOTES: (1) This value will be used for determining the impacts of the proposed development on conveyance system capacity.
(2) This value will be used for determining the impacts of the proposed development on treatment plant capacity.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 3
SANITARY SEWER ANALYSIS

TABLE 3.0
EXISTING FLOW TO SUNNYVALE METERING STATION
AVERAGE AND PEAK SANITARY SEWER FLOWS

Table 3.0 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
Based on Meter Records for the Sunnyvale Pump Station; Sewer Generation is based on August and September sewer flows.

NASA Research Park - including Shenandoah Plaza
Flow to Meter: 326,327 gallons/day
Total acreage: 357.9 acres
Sewer Generation per Acre: 911.8 gallons/acre/day

| TABLE 3.0 A | | | | | | | | |
|---------------------------------------|--------------------|---------------------|--------------------------------------|--------------------------------------|---------------------------------------|------------------|--|-----------------------------------|
| Project Area | Area | Unit Sewer Flow | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
| Lab Area | 27.9 acres | 912 gpd/acre | 25,439 | 18 | 44 | 28 | 59 | 103 |
| NRP South of Shenandoah excluding Lab | 101.7 acres | 912 gpd/acre | 92,728 | 64 | 161 | 102 | 214 | 375 |
| Subtotal, Ex NRP South of Shenandoah | 129.6 acres | 912 gpd/acre | 118,167 | 82 | 205 | 130 | 272 | 477 |
| Shenandoah Plaza Excluding Hangar 1 | 68.4 acres | 912 gpd/acre | 62,366 | 43 | 108 | 68 | 144 | 252 |
| Southern & Eastern Portion of Ames | 64.3 acres | 912 gpd/acre | 58,628 | 41 | 102 | 64 | 135 | 237 |
| Berry Court Military Housing | 36.8 acres | 912 gpd/acre | 33,554 | 23 | 58 | 37 | 77 | 136 |
| California Air National Guard | 41.5 acres | 912 gpd/acre | 37,839 | 26 | 66 | 42 | 87 | 153 |
| East Airfield Excluding Hangars 2 & 3 | 17.3 acres | 912 gpd/acre | 15,774 | 11 | 27 | 17 | 36 | 64 |
| Total to Sunnyvale Meter | 357.9 acres | 912 gpd/acre | 326,327 | 227 | 567 | 358 | 752 | 1318 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 3.0 B - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
Based on Estimated Building Areas

| TABLE 3.0 B | | | | | | | | |
|---------------------------------------|--------------|-----------------|--------------------------------------|--------------------------------------|---------------------------------------|------------------|--|-----------------------------------|
| Project Area | Area | Unit Sewer Flow | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
| Lab Area | 222,252 sf | 0.128 gpd/sf | 28,448 | 20 | 49 | 28 | 59 | 108 |
| NRP South of Shenandoah excluding Lab | 810,143 sf | 0.128 gpd/sf | 103,698 | 72 | 180 | 102 | 214 | 394 |
| Subtotal, Ex NRP South of Shenandoah | 1,032,394 sf | 0.128 gpd/sf | 132,146 | 92 | 229 | 130 | 272 | 502 |
| Shenandoah Plaza Excluding Hangar 1 | 544,875 sf | 0.128 gpd/sf | 69,744 | 48 | 121 | 68 | 144 | 265 |
| Southern & Eastern Portion of Ames | 801,000 sf | 0.046 gpd/sf | 36,738 | 26 | 64 | 64 | 135 | 199 |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 17 | 43 | 37 | 77 | 120 |
| California Air National Guard | 42 acres | 912 gpd/acre | 37,839 | 26 | 66 | 42 | 87 | 153 |
| East Airfield Excluding Hangars 2 & 3 | 79,023 sf | 0.128 gpd/sf | 10,115 | 7 | 18 | 17 | 36 | 54 |
| Hangars 2 & 3 | 780,613 sf | 0.020 gpd/sf | 15,612 | 11 | 27 | 17 | 36 | 63 |
| Total to Sunnyvale Meter | | | 326,945 | 227 | 568 | 375 | 788 | 1356 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 3.0 C - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
From Meter Readings and Calculations

| TABLE 3.0 C | | | | | |
|--------------------------------------|--|------------------|--|-------------------------------------|-----------------------------------|
| | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
| Total Flow from Existing Development | 326,327 | 358 | 1,500 | 536,850 | 0.86 |
| Total to Sunnyvale Meter | 326,327 | 358 | | 536,850 | 0.86 |

Notes: (1) From Table 3.0 A
(2) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 3
SANITARY SEWER ANALYSIS

TABLE 3.1
BASELINE FLOW TO SUNNYVALE METERING STATION - ALTERNATE 1
AVERAGE AND PEAK SANITARY SEWER FLOWS

Table 3.1 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
Based on Meter Records for the Sunnyvale Pump Station; Sewer Generation is based on August, September and October sewer flows.

| TABLE 3.1 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|--|--------------|-----------------|---|---|--|------------------------|---|--|
| Development Area \ Description | Area | Unit Sewer Flow | | | | | | |
| LAB | | | | | | | | |
| Office/High Density R&D | 690,000 sf | 0.10 gpd/sf | 69,000 | 48 | 120 | | | |
| Auditorium | 30,000 sf | 0.05 gpd/sf | 1,500 | 1 | 3 | | | |
| Subtotal, Lab | 720,000 sf | | 70,500 | 49 | 122 | 28 | 15 | 137 |
| NASA RESEARCH PARK | | | | | | | | |
| Existing Buildings | 1,129,962 sf | 0.13 gpd/sf | 144,635 | 100 | 251 | | | |
| Invisible Studios | 105,000 sf | 0.10 gpd/sf | 10,500 | 7 | 18 | | | |
| Subtotal, NRP | 1,234,962 sf | | 155,135 | 108 | 269 | 171 | 359 | 628 |
| Subtotal, Lab and NRP | 1,954,962 sf | | 225,635 | 157 | 392 | 199 | 374 | 765 |
| Southern & Eastern Portion of Ames | 801,000 sf | 0.05 gpd/sf | 36,738 | 26 | 64 | 64 | 135 | 199 |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 17 | 43 | 37 | 77 | 120 |
| Subtotal to New SS Pump Station | | | 287,124 | 199 | 498 | 300 | 586 | 1084 |
| EASTSIDE/AIRFIELD | | | | | | | | |
| East Airfield Excluding Hangars 2 & 3 | 79,023 sf | 0.13 gpd/sf | 10,115 | 7 | 18 | | | |
| Hangars 2 & 3 | 780,613 sf | 0.02 gpd/sf | 15,612 | 11 | 27 | | | |
| Subtotal, EastSide/Airfield | 780,613 sf | | 25,727 | 18 | 45 | 17 | 36 | 81 |
| Air National Guard | 42 acres | 912 gpd/acre | 38,295 | 27 | 66 | 42 | 87 | 154 |
| Total to Existing SS Pump Station | | | 351,146 | 244 | 610 | 359 | 709 | 1319 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 3.1 B - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
From Meter Readings and Calculations

| TABLE 3.1 B | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|--------------------------------------|---|------------------------|---|--|--|
| Total Flow from Existing Development | 280,646 | 331 | 1500 | 496,350 | 0.78 |
| Total Flow from Proposed Development | 70,500 | 28 | 750 | 21,000 | 0.09 |
| Total to Sunnyvale Meter | 351,146 | 359 | | 517,350 | 0.87 |

Notes: (1) From Table 3.1 A
(2) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

The recommended mitigation for NASA Research Park is the installation of new sanitary sewer piping throughout the entire development area, including Shenandoah Plaza. This will reduce the inflow and infiltration into the system. However, for this study, we are assuming that inflow and infiltration will not be reduced in Shenandoah Plaza, in order to allow for the possibility that it could be the last area to develop. For the remainder of NASA Research Park, we have assumed that inflow and infiltration will only be reduced in the portion of the site that will be developed.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 3
SANITARY SEWER ANALYSIS

TABLE 3.2
PROPOSED FLOW TO SUNNYVALE METERING STATION - ALTERNATE 2
AVERAGE AND PEAK SANITARY SEWER FLOWS

Table 3.2 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
Based on Meter Records for the Sunnyvale Pump Station; Sewer Generation is based on August, September and October sewer flows.

| TABLE 3.2 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|------------------------------------|--------------|-----------------|--------------------------------------|--------------------------------------|---------------------------------------|------------------|--|-----------------------------------|
| Development Area \ Description | Area | Unit Sewer Flow | | | | | | |
| LAB | | | | | | | | |
| Office/High Density R&D | 690,000 sf | 0.10 gpd/sf | 69,000 | 48 | 120 | | | |
| Auditorium | 30,000 sf | 0.05 gpd/sf | 1,500 | 1 | 3 | | | |
| Subtotal, Lab | 720,000 sf | | 70,500 | 49 | 122 | 28 | 15 | 137 |
| NASA RESEARCH PARK | | | | | | | | |
| Existing Buildings | 112,990 sf | 0.13 gpd/sf | 14,463 | 10 | 25 | | | |
| Invisible Studios | 105,000 sf | 0.10 gpd/sf | 10,500 | 7 | 18 | | | |
| Office/High Density R&D | | | | | | | | |
| Historic Infill | 100,000 sf | 0.10 gpd/sf | 10,000 | 7 | 17 | | | |
| Space Camp | 140,000 sf | 0.10 gpd/sf | 14,000 | 10 | 24 | | | |
| Gateway Parcels | 262,010 sf | 0.10 gpd/sf | 26,201 | 18 | 45 | | | |
| University Office | 352,800 sf | 0.10 gpd/sf | 35,280 | 25 | 61 | | | |
| University Classroom | 487,200 sf | 0.10 gpd/sf | 48,720 | 34 | 85 | | | |
| Museum (Computer) | 70,000 sf | 0.05 gpd/sf | 3,500 | 2 | 6 | | | |
| Museum (CASC) | 390,000 sf | 0.05 gpd/sf | 19,500 | 14 | 34 | | | |
| Conference Center | 200,000 sf | 0.05 gpd/sf | 10,000 | 7 | 17 | | | |
| Part Time Housing (1 unit/800 sf) | 150,000 sf | 150.00 gpd/unit | 28,125 | 20 | 49 | | | |
| Family Housing (1 unit/1,200 sf) | 360,000 sf | 180.00 gpd/unit | 54,000 | 38 | 94 | | | |
| Retail (University) | 50,000 sf | 0.10 gpd/sf | 5,000 | 3 | 9 | | | |
| Area with Existing System | | | | | | 69 | 145 | |
| Area with New System | | | | | | 102 | 53 | |
| Subtotal, NRP | 2,780,000 sf | | 279,289 | 194 | 485 | 171 | 198 | 683 |
| Subtotal, Lab and NRP | 3,500,000 sf | | 349,789 | 243 | 607 | 199 | 213 | 820 |
| Southern & Eastern Portion of Ames | 801,000 sf | 0.05 gpd/sf | 36,738 | 26 | 64 | 64 | 135 | 199 |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 17 | 43 | 37 | 77 | 120 |
| Subtotal to New SS Pump Station | | | 411,277 | 286 | 714 | 300 | 425 | 1139 |
| EASTSIDE/AIRFIELD | | | | | | | | |
| Existing Buildings | 79,023 sf | 0.13 gpd/sf | 10,115 | 7 | 18 | 17 | 36 | |
| Low Density R&D/Industrial | 890,613 sf | 0.08 gpd/sf | 71,249 | 49 | 124 | | | |
| Office/High Density R&D | 360,000 sf | 0.10 gpd/sf | 36,000 | 25 | 63 | | | |
| Conference Center | 80,000 sf | 0.05 gpd/sf | 4,000 | 3 | 7 | | | |
| Area with New System | | | | | | 72 | 37 | |
| Subtotal, EastSide/Airfield | 1,409,636 sf | | 121,364 | 84 | 211 | 89 | 73 | 284 |
| California Air National Guard | 42 acres | 912 gpd/acre | 38,295 | 27 | 66 | 42 | 87 | 154 |
| Total to EX SS Pump Station | | | 570,936 | 396 | 991 | 431 | 585 | 1576 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 3.2 B - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
From Meter Readings and Calculations

| TABLE 3.2 B | | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|--------------------------------------|--|--|------------------|--|-------------------------------------|-----------------------------------|
| Total Flow from Existing Development | | 124,361 | 229 | 1500 | 342,900 | 0.47 |
| Total Flow from Proposed Development | | 446,575 | 202 | 750 | 151,500 | 0.60 |
| Total to Sunnyvale Meter | | 570,936 | 431 | | 494,400 | 1.07 |

Notes: (1) From Table 3.2 A
(2) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

The recommended mitigation for NASA Research Park is the installation of new sanitary sewer piping throughout the entire development area, including Shenandoah Plaza. This will reduce the inflow and infiltration into the system. However, for this study, we are assuming that inflow and infiltration will not be reduced in Shenandoah Plaza, in order to allow for the possibility that it could be the last area to develop. For the remainder of NASA Research Park, we have assumed that inflow and infiltration will only be reduced in the portion of the site that will be developed.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 3
SANITARY SEWER ANALYSIS

TABLE 3.3
PROPOSED FLOW TO SUNNYVALE METERING STATION - ALTERNATE 3
AVERAGE AND PEAK SANITARY SEWER FLOWS

Table 3.3 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
Based on Meter Records for the Sunnyvale Pump Station; Sewer Generation is based on August, September and October sewer flows.

| TABLE 3.3 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|------------------------------------|--------------|-----------------|---|---|--|------------------------|---|--|
| Development Area \ Description | Area | Unit Sewer Flow | | | | | | |
| LAB | | | | | | | | |
| Office/High Density R&D | 690,000 sf | 0.10 gpd/sf | 69,000 | 48 | 120 | | | |
| Auditorium | 30,000 sf | 0.05 gpd/sf | 1,500 | 1 | 3 | | | |
| Subtotal, Lab | 720,000 sf | | 70,500 | 49 | 122 | 28 | 15 | 137 |
| NASA RESEARCH PARK | | | | | | | | |
| Existing Buildings | 112,990 sf | 0.13 gpd/sf | 14,463 | 10 | 25 | | | |
| Invisible Studios | 105,000 sf | 0.10 gpd/sf | 10,500 | 7 | 18 | | | |
| Office/High Density R&D | | | | | | | | |
| Historic Infill | 115,000 sf | 0.10 gpd/sf | 11,500 | 8 | 20 | | | |
| Space Camp | 200,000 sf | 0.10 gpd/sf | 20,000 | 14 | 35 | | | |
| Gateway Parcels | 362,010 sf | 0.10 gpd/sf | 36,201 | 25 | 63 | | | |
| Parcel 9 | 750,000 sf | 0.10 gpd/sf | 75,000 | 52 | 130 | | | |
| University Office | 352,800 sf | 0.10 gpd/sf | 35,280 | 25 | 61 | | | |
| University Classroom | 487,200 sf | 0.10 gpd/sf | 48,720 | 34 | 85 | | | |
| Museum (Computer) | 70,000 sf | 0.05 gpd/sf | 3,500 | 2 | 6 | | | |
| Museum (CASC) | 390,000 sf | 0.05 gpd/sf | 19,500 | 14 | 34 | | | |
| Conference Center | 250,000 sf | 0.05 gpd/sf | 12,500 | 9 | 22 | | | |
| Part Time Housing (1 unit/800 sf) | 150,000 sf | 150.00 gpd/unit | 28,125 | 20 | 49 | | | |
| Family Housing (1 unit/1,200 sf) | 360,000 sf | 180.00 gpd/unit | 54,000 | 38 | 94 | | | |
| Retail (University) | 75,000 sf | 0.10 gpd/sf | 7,500 | 5 | 13 | | | |
| Area with Existing System | | | | | | 69 | 145 | |
| Area with New System | | | | | | 102 | 53 | |
| Subtotal, NRP | 3,780,000 sf | | 376,789 | 262 | 654 | 171 | 198 | 852 |
| Subtotal, Lab and NRP | 4,500,000 sf | | 447,289 | 311 | 777 | 199 | 213 | 989 |
| Southern & Eastern Portion of Ames | 801,000 sf | 0.05 gpd/sf | 36,738 | 26 | 64 | 64 | 135 | 199 |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 17 | 43 | 37 | 77 | 120 |
| Subtotal to New SS Pump Station | | | 508,777 | 353 | 883 | 300 | 425 | 1308 |
| EASTSIDE/AIRFIELD | | | | | | | | |
| Existing Buildings | 79,023 sf | 0.13 gpd/sf | 10,115 | 7 | 18 | 17 | 36 | |
| Low Density R&D/Industrial | 780,613 sf | 0.08 gpd/sf | 62,449 | 43 | 108 | | | |
| Area with New System | | | | | | 32 | 17 | |
| Subtotal, EastSide/Airfield | 859,636 sf | | 72,564 | 50 | 126 | 49 | 52 | 178 |
| California Air National Guard | 42 acres | 912 gpd/acre | 38,295 | 27 | 66 | 42 | 87 | 154 |
| Total to EX SS Pump Station | | | 619,636 | 430 | 1076 | 391 | 564 | 1640 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 3.3 B - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
From Meter Readings and Calculations

| TABLE 3.3 B | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|--------------------------------------|---|------------------------|---|--|--|
| Total Flow from Existing Development | 124,361 | 229 | 1500 | 342,900 | 0.47 |
| Total Flow from Proposed Development | 495,275 | 162 | 750 | 121,500 | 0.62 |
| Total to Sunnyvale Meter | 619,636 | 391 | | 464,400 | 1.08 |

Notes: (1) From Table 3.3. A
(2) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

The recommended mitigation for NASA Research Park is the installation of new sanitary sewer piping throughout the entire development area, including Shenandoah Plaza. This will reduce the inflow and infiltration into the system. However, for this study, we are assuming that inflow and infiltration will not be reduced in Shenandoah Plaza, in order to allow for the possibility that it could be the last area to develop. For the remainder of NASA Research Park, we have assumed that inflow and infiltration will only be reduced in the portion of the site that will be developed.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 3
SANITARY SEWER ANALYSIS

TABLE 3.4
PROPOSED FLOW TO SUNNYVALE METERING STATION - ALTERNATE 4
AVERAGE AND PEAK SANITARY SEWER FLOWS

Table 3.4 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
Based on Meter Records for the Sunnyvale Pump Station; Sewer Generation is based on August, September and October sewer flows.

| TABLE 3.4 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|------------------------------------|--------------|-----------------|---|---|--|------------------------|---|--|
| Development Area \ Description | Area | Unit Sewer Flow | | | | | | |
| LAB | | | | | | | | |
| Office/High Density R&D | 690,000 sf | 0.10 gpd/sf | 69,000 | 48 | 120 | | | |
| Auditorium | 30,000 sf | 0.05 gpd/sf | 1,500 | 1 | 3 | | | |
| Subtotal, Lab | 720,000 sf | | 70,500 | 49 | 122 | 28 | 15 | 137 |
| NASA RESEARCH PARK | | | | | | | | |
| Existing Buildings | 112,990 sf | 0.13 gpd/sf | 14,463 | 10 | 25 | | | |
| Invisible Studios | 105,000 sf | 0.10 gpd/sf | 10,500 | 7 | 18 | | | |
| Office/High Density R&D | | | | | | | | |
| Historic Infill | 50,000 sf | 0.10 gpd/sf | 5,000 | 3 | 9 | | | |
| Space Camp | 55,000 sf | 0.10 gpd/sf | 5,500 | 4 | 10 | | | |
| Gateway Parcels | 97,010 sf | 0.10 gpd/sf | 9,701 | 7 | 17 | | | |
| University Office | 336,000 sf | 0.10 gpd/sf | 33,600 | 23 | 58 | | | |
| University Classroom | 464,000 sf | 0.10 gpd/sf | 46,400 | 32 | 81 | | | |
| Museum (Computer) | 70,000 sf | 0.05 gpd/sf | 3,500 | 2 | 6 | | | |
| Museum (CASC) | 390,000 sf | 0.05 gpd/sf | 19,500 | 14 | 34 | | | |
| Conference Center | 185,000 sf | 0.05 gpd/sf | 9,250 | 6 | 16 | | | |
| Part Time Housing (1 unit/800 sf) | 115,000 sf | 150.00 gpd/unit | 21,563 | 15 | 37 | | | |
| Family Housing (1 unit/1,200 sf) | 265,000 sf | 180.00 gpd/unit | 39,750 | 28 | 69 | | | |
| Retail (University) | 35,000 sf | 0.10 gpd/sf | 3,500 | 2 | 6 | | | |
| Area with Existing System | | | | | | 69 | 145 | |
| Area with New System | | | | | | 102 | 53 | |
| Subtotal, NRP | 2,280,000 sf | | 222,226 | 154 | 386 | 171 | 198 | 584 |
| Subtotal, Lab and NRP | 3,000,000 sf | | 292,726 | 203 | 508 | 199 | 213 | 721 |
| Southern & Eastern Portion of Ames | 801,000 sf | 0.05 gpd/sf | 36,738 | 26 | 64 | 64 | 135 | 199 |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 17 | 43 | 37 | 77 | 120 |
| Subtotal to New SS Pump Station | | | 354,215 | 246 | 615 | 300 | 425 | 1040 |
| EASTSIDE/AIRFIELD | | | | | | | | |
| Existing Buildings | 79,023 sf | 0.13 gpd/sf | 10,115 | 7 | 18 | 17 | 36 | |
| Low Density R&D/Industrial | 890,613 sf | 0.08 gpd/sf | 71,249 | 49 | 124 | | | |
| Conference Center | 80,000 | 0.05 gpd/sf | 4,000 | 3 | 7 | | | |
| Office/High Density R&D | 480,000 | 0.10 gpd/sf | 48,000 | 33 | 83 | | | |
| Area with New System | | | | | | 72 | 37 | |
| Subtotal, EastSide/Airfield | 1,529,636 sf | | 133,364 | 93 | 232 | 89 | 73 | 305 |
| California Air National Guard | 42 acres | 912 gpd/acre | 38,295 | 27 | 66 | 42 | 87 | 154 |
| Total to EX SS Pump Station | | | 525,873 | 365 | 913 | 431 | 585 | 1498 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 3.4 B - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
From Meter Readings and Calculations

| TABLE 3.4 B | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|--------------------------------------|---|------------------------|---|--|--|
| Total Flow from Existing Development | 124,361 | 229 | 1500 | 342,900 | 0.47 |
| Total Flow from Proposed Development | 401,513 | 202 | 750 | 151,500 | 0.55 |
| Total to Sunnyvale Meter | 525,873 | 431 | | 494,400 | 1.02 |

Notes: (1) From Table 3.4 A
(2) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

The recommended mitigation for NASA Research Park is the installation of new sanitary sewer piping throughout the entire development area, including Shenandoah Plaza. This will reduce the inflow and infiltration into the system. However, for this study, we are assuming that inflow and infiltration will not be reduced in Shenandoah Plaza, in order to allow for the possibility that it could be the last area to develop. For the remainder of NASA Research Park, we have assumed that inflow and infiltration will only be reduced in the portion of the site that will be developed.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 3
SANITARY SEWER ANALYSIS**

**TABLE 3.5
PROPOSED FLOW TO SUNNYVALE METERING STATION - ALTERNATE 5
AVERAGE AND PEAK SANITARY SEWER FLOWS**

Table 3.5 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
Based on Meter Records for the Sunnyvale Pump Station; Sewer Generation is based on August, September and October sewer flows.

| TABLE 3.5 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|--|--------------|-----------------|---|---|--|------------------------|---|--|
| Development Area \ Description | Area | Unit Sewer Flow | | | | | | |
| LAB | | | | | | | | |
| Office/High Density R&D | 690,000 sf | 0.10 gpd/sf | 69,000 | 48 | 120 | | | |
| Auditorium | 30,000 sf | 0.05 gpd/sf | 1,500 | 1 | 3 | | | |
| Subtotal, Lab | 720,000 sf | | 70,500 | 49 | 122 | 28 | 15 | 137 |
| NASA RESEARCH PARK | | | | | | | | |
| Existing Buildings | 54,355 sf | 0.13 gpd/sf | 6,957 | 5 | 12 | | | |
| Invisible Studios | 105,000 sf | 0.10 gpd/sf | 10,500 | 7 | 18 | | | |
| Office/High Density R&D | | | | | | | | |
| Historic Infill | 155,000 sf | 0.10 gpd/sf | 15,500 | 11 | 27 | | | |
| Space Camp | 70,000 sf | 0.10 gpd/sf | 7,000 | 5 | 12 | | | |
| Other | 223,645 sf | 0.10 gpd/sf | 22,365 | 16 | 39 | | | |
| University Office | 406,560 sf | 0.10 gpd/sf | 40,656 | 28 | 71 | | | |
| University Classroom | 561,440 sf | 0.10 gpd/sf | 56,144 | 39 | 97 | | | |
| Museum (Computer) | 120,000 sf | 0.05 gpd/sf | 6,000 | 4 | 10 | | | |
| Museum (CASC) | 500,000 sf | 0.05 gpd/sf | 25,000 | 17 | 43 | | | |
| Conference Center | 250,000 sf | 0.05 gpd/sf | 12,500 | 9 | 22 | | | |
| Part Time Housing (1 unit/800 sf) | 232,000 sf | 150.00 gpd/unit | 43,500 | 30 | 76 | | | |
| Retail (University) | 50,000 sf | 0.10 gpd/sf | 5,000 | 3 | 9 | | | |
| Retail (Gateway & Historic Infill) | 27,000 sf | 0.10 gpd/sf | 2,700 | 2 | 5 | | | |
| Recreation (Conference Center) | 25,000 sf | 0.05 gpd/sf | 1,250 | 1 | 2 | | | |
| Area with Existing System | | | | | | 69 | 145 | |
| Area with New System | | | | | | 102 | 53 | |
| Subtotal, NRP | 2,780,000 sf | | 255,072 | 177 | 443 | 171 | 198 | 641 |
| Subtotal, Lab and NRP | 3,500,000 sf | | 325,572 | 226 | 565 | 199 | 213 | 778 |
| Southern & Eastern Portion of Ames | 801,000 sf | 0.05 gpd/sf | 36,738 | 26 | 64 | 64 | 135 | 199 |
| Berry Court Military Housing | 110 units | 225.00 gpd/unit | 24,750 | 17 | 43 | 37 | 77 | 120 |
| Subtotal to New SS Pump Station | | | 387,060 | 269 | 672 | 300 | 425 | 1097 |
| EASTSIDE/AIRFIELD | | | | | | | | |
| Existing Buildings Excluding Hangars 2 & 3 | 79,023 sf | 0.13 gpd/sf | 10,115 | 7 | 18 | 17 | 36 | |
| Hangars 2 & 3 | 780,613 sf | 0.02 gpd/sf | 15,612 | 11 | 27 | | | |
| Control Tower | 12,000 sf | 0.08 gpd/sf | 960 | 1 | 2 | | | |
| Area with New System | | | | | | 5 | 3 | |
| Subtotal, EastSide/Airfield | 871,636 sf | | 26,687 | 19 | 46 | 22 | 39 | 85 |
| California Air National Guard | 42 acres | 912 gpd/acre | 38,295 | 27 | 66 | 42 | 87 | 154 |
| Total to EX SS Pump Station | | | 452,042 | 314 | 785 | 364 | 551 | 1336 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 3.5 B - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
From Meter Readings and Calculations

| TABLE 3.5 B | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|--------------------------------------|---|------------------------|---|--|--|
| Total Flow from Existing Development | 116,856 | 229 | 1500 | 343,350 | 0.46 |
| Total Flow from Proposed Development | 319,575 | 135 | 750 | 101,250 | 0.42 |
| Total to Sunnyvale Meter | 436,430 | 364 | | 444,600 | 0.88 |

Notes: (1) From Table 3.5 A
(2) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

The recommended mitigation for NASA Research Park is the installation of new sanitary sewer piping throughout the entire development area, including Shenandoah Plaza. This will reduce the inflow and infiltration into the system. However, for this study, we are assuming that inflow and infiltration will not be reduced in Shenandoah Plaza, in order to allow for the possibility that it could be the last area to develop. For the remainder of NASA Research Park, we have assumed that inflow and infiltration will only be reduced in the portion of the site that will be developed.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 3
SANITARY SEWER ANALYSIS**

**TABLE 3.6
FLOW TO SUNNYVALE FROM PENDING PROJECTS
AVERAGE AND PEAK SANITARY SEWER FLOWS**

Table 3.6 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant (Adjacent Projects)
From Calculations

| TABLE 3.6 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | *Equivalent Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|--|---------------------|-----------------|---|---|--|---------------------------------------|---|--|
| Development Area \ Description | **Area | Unit Demand | | | | | | |
| Office/High Density R&D | 4,016,778 sf | 0.10 gpd/sf | 401,678 | 279 | 697 | 446.3 | 310 | 1007 |
| Hotel/Apartment (30 units @ 1,000 sf/unit) | 30,000 sf | 165.00 gpd/unit | 4,950 | 3 | 9 | 3.3 | 2 | 11 |
| Total Pending Projects in Sunnyvale | 4,046,778 sf | | 406,628 | 282 | 706 | 450 | 312 | 1018 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 1,000 gpd/acre for new systems (conservative value relative to 750 gpd/acre).

Table 3.6 B - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant (All City Projects)
From Calculations

| TABLE 3.6 B | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | *Equivalent Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|---|----------------------|-----------------|---|---|--|---------------------------------------|---|--|
| Development Area \ Description | **Area | Unit Demand | | | | | | |
| Office/High Density R&D | 6,172,060 sf | 0.10 gpd/sf | 617,206 | 429 | 1072 | 685.8 | 476 | 1547 |
| Moffett Park | 28,600,000 sf | 0.10 gpd/sf | 2,860,000 | 1986 | 4965 | 3177.8 | 2205 | 7171 |
| Retail | 562,397 sf | 0.10 gpd/sf | 56,240 | 39 | 98 | 62.5 | 43 | 141 |
| Hotel/Apartment (820 units @ 1,000 sf/unit) | 820,000 sf | 165.00 gpd/unit | 135,300 | 94 | 235 | 91.1 | 63 | 298 |
| Condo/Townhomes/Homes (316 units @ 1,200 sf/unit) | 379,200 sf | 180.00 gpd/unit | 56,880 | 40 | 99 | 42.1 | 29 | 128 |
| Child Care | 15,000 sf | 0.05 gpd/sf | 750 | 1 | 1 | 1.7 | 1 | 2 |
| Total Pending Projects in Sunnyvale | 36,548,657 sf | | 3,726,376 | 2588 | 6469 | 4061 | 2818 | 9288 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 1,000 gpd/acre for new systems (conservative value relative to 750 gpd/acre).

Table 3.6 C - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
From Calculations

| TABLE 3.6 C | Average Dry Weather Sewer Flow (gpd) (1) | *Equivalent Land Area (acre) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|---|---|---------------------------------------|---|--|--|
| Total Flow from Pending Projects | 3,726,376 | 4061 | 1000 | 4,060,962 | 7.79 |

Notes: (1) From Table 3.6 B
(2) Daily I/I = 1,000 gpd/acre for new systems (conservative value relative to 750 gpd/acre).

*Equivalent land area based on 9,000 sf/acre

**Square footages based on September 2001 development update from Sunnyvale Planning Department.

A P P E N D I X C 4

SANITARY SEWER DEMAND -
WESTERN/MOUNTAIN VIEW

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 4
SANITARY SEWER ANALYSIS
SUMMARY
SANITARY SEWER DEMAND - WESTERN / MOUNTAIN VIEW SYSTEM**

Area Flowing to Mountain View

Approximately 350 acres of NASA Ames Research Center currently discharge sanitary sewer to the system operated by the City of Mountain View. The contributing areas are listed below.

| Project Areas Flowing to Mountain View | Area |
|---|-----------|
| Bay View | 95 acres |
| Northern & Western Portion of Ames Campus | 176 acres |
| Orion Park Military Housing | 79 acres |
| Total to Mountain View System | 350 acres |

Summary of Existing and Proposed Sanitary Sewer flows

Existing flows were determined based on meter readings at the metering station located at the northwest corner of the project site, which discharges into a City of Mountain View sewer main. Proposed flows for the various alternates are based on calculations shown on the spreadsheets on the following pages.

| Development Alternate | Conveyance System Peak Wet Weather Sewer Flow (gpm) (1) | Treatment Plant Peak Wet Weather Sewer Flow (MGD) (2) |
|------------------------|--|--|
| 1- Baseline (Existing) | 872 gpm | 0.58 MGD |
| 2 | 1173 gpm | 0.79 MGD |
| 3 | 872 gpm | 0.58 MGD |
| 4 | 1447 gpm | 0.95 MGD |
| 5 - Preferred | 1178 gpm | 0.85 MGD |

- NOTES: (1) This value will be used for determining the impacts of the proposed development on conveyance system capacity.
(2) This value will be used for determining the impacts of the proposed development on treatment plant capacity.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 4
SANITARY SEWER ANALYSIS

TABLE 4.1
EXISTING FLOW TO MOUNTAIN VIEW FROM NASA ARC - ALTERNATE 1
AVERAGE AND PEAK SANITARY SEWER FLOWS

Table 4.1 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant From Meter Readings and Calculations

| TABLE 4.1 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|-----------------------------------|--------------|-----------------|--------------------------------------|--------------------------------------|---------------------------------------|------------------|--|-----------------------------------|
| Development Area \ Description | Area | Unit Demand | | | | | | |
| Ames Campus | | | | | | | | |
| Existing Buildings | 2,088,658 sf | 0.046 gpd/sf | 95,798 | 67 | 166 | 176 | 370 | 536 |
| Ex Buildings flowing to Sunnyvale | 801,000 sf | | | | | | | |
| Subtotal, Ames Campus | 2,889,658 sf | | 95,798 | 67 | 166 | 176 | 370 | 536 |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 68 | 170 | 79 | 166 | 336 |
| Total Leaving NASA ARC | | | 193,673 | 134 | 336 | 255 | 536 | 872 |

- Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.
(3) Flow to Mountain View, Corrected. 95,798 gpd to meter

Table 4.1 B - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant From 1991 City of Mountain View Sanitary Sewer Master Plan

| TABLE 4.1 B | | 1990 Peak Dry Weather Flow (MGD) | 1990 Peak Wet Weather Flow (MGD) | 1990 Peak Wet Weather Flow (gpm) | 2010 Peak Dry Weather Flow (MGD) | 2010 Peak Wet Weather Flow (MGD) | 2010 Peak Wet Weather Flow (gpm) |
|-------------------------------|--------------------------|----------------------------------|----------------------------------|----------------------------------|----------------------------------|----------------------------------|----------------------------------|
| City's Model | Station per City's Model | | | | | | |
| at Entrance to NASA ARC | 650030 | 3.18 | 3.81 | 2646 | 3.72 | 4.05 | 2813 |
| at Exit from NASA ARC | 250200 | 3.29 | 4.08 | 2833 | 3.96 | 4.50 | 3125 |
| Total Leaving NASA ARC | | 0.11 | 0.27 | 188 | 0.24 | 0.45 | 313 |

Comparison of BKF Calculations and Mountain View Master Plan

The City's model indicates a 1990 peak dry weather flow of 110,000 gpd (0.11 MGD). However, meter records for the Moffett Meter show that the average dry weather flow is approximately 100,000 gpd for the metered portion of Ames Research Center alone (Table 4.7). The Orion Park Military Housing adds another 100,000 gpd average dry weather flow (Table 4.1 A). Therefore the total average dry weather flow leaving NASA ARC is 200,000 gpd. This equates to a peak dry weather flow of about 400,000 gpd, which is almost 4 times the flow indicated by the City's model.

Meter records for the Moffett Meter were also reviewed for peak wet weather flows. Unfortunately, during peak flows the Mountain View lift station that is located downstream of the Moffett Meter operates in a gravity bypass mode which allows flow to back up to the Moffett Meter. This necessitates close examination of the meter readings to identify the false peaks that result from the backup. The calculations in Table 4.1 A incorporate BKF's interpretation of the meter readings for wet weather flows and more closely reflect the true existing peak wet weather flow. This value will be used for determining the impacts of the proposed development on conveyance system capacity.

Table 4.1 C - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant From Meter Readings and Calculations

| TABLE 4.1 C | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|--------------------------------------|--|------------------|--|-------------------------------------|-----------------------------------|
| Total Flow from Existing Development | 193,673 | 255 | 1500 | 382,500 | 0.58 |
| Total Leaving NASA ARC | 193,673 | 255 | | 382,500 | 0.58 |

- Note: (1) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

The calculations in Table 4.1 C for the peak daily flow leaving the site are based on the reasoning outlined in the paragraphs above. This value reflects BKF's estimate of the true existing peak wet weather flow and will be used for determining the impacts of the proposed development on treatment plant capacity.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 4
SANITARY SEWER ANALYSIS

TABLE 4.2
PROPOSED FLOW TO MOUNTAIN VIEW - ALTERNATE 2
AVERAGE AND PEAK SANITARY SEWER FLOWS

Table 4.2 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
 From Meter Readings and Calculations

| TABLE 4.2 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|-----------------------------------|--------------|-----------------|---|---|--|------------------------|---|--|
| Development Area \ Description | Area | Unit Demand | | | | | | |
| Ames Campus | | | | | | | | |
| Existing Buildings | 2,088,658 sf | 0.046 gpd/sf | 95,798 | 67 | 166 | 176 | 370 | 536 |
| Ex Buildings flowing to Sunnyvale | 801,000 sf | | | | | | | |
| Subtotal, Ames Campus | 2,889,658 sf | | 95,798 | 67 | 166 | 176 | 370 | 536 |
| BAY VIEW | | | | | | | | |
| Office/High Density R&D | 500,000 sf | 0.10 gpd/sf | 50,000 | 35 | 87 | | | |
| University Office | 210,000 sf | 0.10 gpd/sf | 21,000 | 15 | 36 | | | |
| University Classroom | 290,000 sf | 0.10 gpd/sf | 29,000 | 20 | 50 | | | |
| Family Housing (1 unit/1200 sf) | 300,000 sf | 180.00 gpd/unit | 45,000 | 31 | 78 | | | |
| Subtotal, Proposed Bay View | 1,300,000 sf | | 145,000 | 101 | 252 | 95 | 49 | 301 |
| Subtotal, ARC & Proposed Bay View | 4,189,658 sf | | 240,798 | 167 | 418 | 271 | 419 | 837 |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 68 | 170 | 79 | 166 | 336 |
| Total Leaving NASA ARC | | | 338,673 | 235 | 588 | 350 | 585 | 1173 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
 (2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 4.2 B - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
 From Meter Readings and Calculations

| TABLE 4.2 B | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) (1) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|--------------------------------------|---|----------------------------|---|--|--|
| Total Flow from Existing Development | 193,673 | 255 | 1500 | 382,500 | 0.58 |
| Total Flow from Proposed Development | 145,000 | 95 | 750 | 70,950 | 0.22 |
| Total Leaving NASA ARC | 338,673 | 350 | | 453,450 | 0.79 |

Notes: (1) From Table 4.2 A
 (2) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 4
SANITARY SEWER ANALYSIS**

**TABLE 4.3
PROPOSED FLOW TO MOUNTAIN VIEW - ALTERNATE 3
AVERAGE AND PEAK SANITARY SEWER FLOWS**

Table 4.3 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
From Meter Readings and Calculations

| TABLE 4.3 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|-----------------------------------|--------------|-----------------|---|---|--|------------------------|---|--|
| Development Area \ Description | Area | Unit Demand | | | | | | |
| Ames Campus | | | | | | | | |
| Existing Buildings | 2,088,658 sf | 0.046 gpd/sf | 95,798 | 67 | 166 | 176 | 370 | 536 |
| Ex Buildings flowing to Sunnyvale | 801,000 sf | | | | | | | |
| Subtotal, Ames Campus | 2,889,658 sf | | 95,798 | 67 | 166 | 176 | 370 | 536 |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 68 | 170 | 79 | 166 | 336 |
| Total Leaving NASA ARC | | | 193,673 | 68 | 170 | 79 | 166 | 872 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
(2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 4.3 B - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
From Meter Readings and Calculations

| TABLE 4.3 B | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) (1) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|--------------------------------------|---|----------------------------|---|--|--|
| Total Flow from Existing Development | 193,673 | 255 | 1500 | 382,500 | 0.58 |
| Total Leaving NASA ARC | 193,673 | 255 | | 382,500 | 0.58 |

Notes: (1) From Table 4.3 A
(2) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 4
SANITARY SEWER ANALYSIS

TABLE 4.4
PROPOSED FLOW TO MOUNTAIN VIEW - ALTERNATE 4
AVERAGE AND PEAK SANITARY SEWER FLOWS

Table 4.4 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
 From Meter Readings and Calculations

| TABLE 4.4 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|------------------------------------|--------------|-----------------|---|---|--|------------------------|---|--|
| Development Area \ Description | Area | Unit Demand | | | | | | |
| Ames Campus | | | | | | | | |
| Existing Buildings | 2,088,658 sf | 0.046 gpd/sf | 95,798 | 67 | 166 | 176 | 370 | 536 |
| Ex Buildings flowing to Sunnysvale | 801,000 sf | | | | | | | |
| Subtotal, Ames Campus | 2,889,658 sf | | 95,798 | 67 | 166 | 176 | 370 | 536 |
| BAY VIEW | | | | | | | | |
| Office/High Density R&D | 1,540,000 sf | 0.10 gpd/sf | 154,000 | 107 | 267 | | | |
| University Office | 126,000 sf | 0.10 gpd/sf | 12,600 | 9 | 22 | | | |
| University Classroom | 174,000 sf | 0.10 gpd/sf | 17,400 | 12 | 30 | | | |
| Family Housing (1 unit/1200 sf) | 660,000 sf | 180.00 gpd/unit | 99,000 | 69 | 172 | | | |
| Low Density R&D/Industrial | 200,000 sf | 0.10 gpd/sf | 20,000 | 14 | 35 | | | |
| Subtotal, Proposed Bay View | 2,700,000 sf | | 303,000 | 210 | 526 | 95 | 49 | 575 |
| Subtotal, ARC & Proposed Bay View | 5,589,658 sf | | 398,798 | 277 | 692 | 271 | 419 | 1111 |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 68 | 170 | 79 | 166 | 336 |
| Total Leaving NASA ARC | | | 496,673 | 345 | 862 | 350 | 585 | 1447 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
 (2) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 4.4 B - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
 From Meter Readings and Calculations

| TABLE 4.4 B | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) (1) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|--------------------------------------|---|----------------------------|---|--|--|
| Total Flow from Existing Development | 193,673 | 255 | 1500 | 382,500 | 0.58 |
| Total Flow from Proposed Development | 303,000 | 95 | 750 | 70,950 | 0.37 |
| Total Leaving NASA ARC | 496,673 | 350 | | 453,450 | 0.95 |

Notes: (1) From Table 4.4 A
 (2) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 4
SANITARY SEWER ANALYSIS

TABLE 4.5
PROPOSED FLOW TO MOUNTAIN VIEW - ALTERNATE 5
AVERAGE AND PEAK SANITARY SEWER FLOWS

Table 4.5 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant
From Meter Readings and Calculations

| TABLE 4.5 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (2) | Land Area (acre) | Peak Inflow and Infiltration (gpm) (3) | Peak Wet Weather Sewer Flow (gpm) |
|-----------------------------------|--------------|-----------------|---|---|--|------------------------|---|--|
| Development Area \ Description | Area | Unit Demand | | | | | | |
| Ames Campus | | | | | | | | |
| Existing Buildings | 1,688,658 sf | (1) | 100,000 | 69 | 174 | 176 | 370 | 543 |
| Ex Buildings flowing to Sunnyvale | 801,000 sf | | | | | | | |
| Office/High Density R&D | 500,000 sf | 0.10 gpd/sf | 50,000 | 35 | 87 | | | |
| Subtotal, Ames Campus | 2,989,658 sf | | 150,000 | 69 | 174 | 176 | 370 | 543 |
| BAY VIEW | | | | | | | | |
| Family Housing (1 unit/1200 sf) | 900,000 sf | 180.00 gpd/sf | 135,000 | 94 | 234 | | | |
| Retail | 75,000 sf | 0.10 gpd/sf | 7,500 | 5 | 13 | | | |
| Child Care | 25,000 sf | 0.05 gpd/sf | 1,250 | 1 | 2 | | | |
| Subtotal, Proposed Bay View | 1,000,000 sf | | 143,750 | 100 | 250 | 95 | 49 | 299 |
| Subtotal, ARC & Proposed Bay View | 3,989,658 sf | | 293,750 | 169 | 423 | 271 | 419 | 842 |
| Orion Park Military Housing | 435 units | 225.00 gpd/unit | 97,875 | 68 | 170 | 79 | 166 | 336 |
| Total Leaving NASA ARC | | | 391,625 | 237 | 593 | 350 | 585 | 1178 |

- Notes: (1) Assume existing Ames Campus flow from Table 4.7 is unchanged and flows from new development are added.
(2) Peak Dry Weather = 2.5 x Average Dry Weather
(3) Peak I/I = 3,000 gpd/acre for existing systems. Peak I/I = 750 gpd/acre for new systems.

Table 4.5 B - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
From Meter Readings and Calculations

| TABLE 4.5 B | Average Dry Weather Sewer Flow (gpd) (1) | Land Area (acre) (1) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|--------------------------------------|---|----------------------------|---|--|--|
| Total Flow from Existing Development | 197,875 | 255 | 1500 | 382,500 | 0.58 |
| Total Flow from Proposed Development | 193,750 | 95 | 750 | 70,950 | 0.26 |
| Total Leaving NASA ARC | 391,625 | 350 | | 453,450 | 0.85 |

- Notes: (1) From Table 4.5 A
(2) Daily I/I = 1,500 gpd/acre for existing systems. Daily I/I = 750 gpd/acre for new systems.

SANITARY SEWER ANALYSIS
TABLE 4.6
FLOW TO MOUNTAIN VIEW FROM PENDING PROJECTS
AVERAGE AND PEAK SANITARY SEWER FLOWS

Table 4.6 A - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant (Adjacent Projects)
 From Calculations

| TABLE 4.6 A | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | *Equivalent Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|--|------------|-------------|---|---|--|---------------------------------------|---|--|
| Development Area \ Description | **Area | Unit Demand | | | | | | |
| Office/High Density R&D | 617,924 sf | 0.10 gpd/sf | 61,792 | 43 | 107 | 68.7 | 48 | 155 |
| Total Pending Projects in Mountain View | 617,924 sf | | 61,792 | 43 | 107 | 68.7 | 48 | 155 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
 (2) Peak I/I = 1,000 gpd/acre for new systems (conservative value relative to 750 gpd/acre).

Table 4.6 B - Peak Wet Weather Flow for Determining Required Capacity of Pipes Conveying Sewage to Treatment Plant (All City Projects)
 From Calculations

| TABLE 4.6 B | | | Average Dry Weather Sewer Flow (gpd) | Average Dry Weather Sewer Flow (gpm) | Peak Dry Weather Sewer Flow (gpm) (1) | *Equivalent Land Area (acre) | Peak Inflow and Infiltration (gpm) (2) | Peak Wet Weather Sewer Flow (gpm) |
|--|--------------|-----------------|---|---|--|---------------------------------------|---|--|
| Development Area \ Description | **Area | Unit Demand | | | | | | |
| Office/High Density R&D | 2,201,000 sf | 0.10 gpd/sf | 220,100 | 153 | 382 | 244.6 | 170 | 552 |
| Retail | 8,820 sf | 0.10 gpd/sf | 882 | 1 | 2 | 1.0 | 1 | 2 |
| Condo/Multi-family (275 units @ 1,200 sf/unit) | 330,000 sf | 180.00 gpd/unit | 49,500 | 34 | 86 | 36.7 | 25 | 111 |
| Total Pending Projects in Mountain View | 2,539,820 sf | | 270,482 | 188 | 470 | 281.2 | 196 | 665 |

Notes: (1) Peak Dry Weather = 2.5 x Average Dry Weather
 (2) Peak I/I = 1,000 gpd/acre for new systems (conservative value relative to 750 gpd/acre).

Table 4.6 C - Peak Wet Weather Flow for Determining Sewage Flowing to Treatment Plant
 From Calculations

| TABLE 4.6 C | Average Dry Weather Sewer Flow (gpd) (1) | *Equivalent Land Area (acre) | Average Inflow and Infiltration (gpd/acre) (2) | Total Inflow and Infiltration (gpd) | Peak Wet Weather Sewer Flow (MGD) |
|---|---|---------------------------------------|---|--|--|
| Total Flow from Pending Projects | 270,482 | 281 | 1000 | 281,222 | 0.55 |

Notes: (1) From Table 4.6 B
 (2) Daily I/I = 1,000 gpd/acre for new systems.

*Equivalent land area based on 9,000 sf/acre

**Square footages based on memorandum from Linda Forsberg, Deputy City Manager, dated September 17, 2000.

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 4
SANITARY SEWER ANALYSIS**

**TABLE 4.7
EXISTING FLOW TO MOUNTAIN VIEW METERING STATION**

| Comparison of Monitoring Results to Mountain View 1991 Sanitary Sewer Master Plan and BKF Model | 1998 Monitoring Results Average Day (MGD) | 1999 Monitoring Results Average Day (MGD) | Report Table 4-2 Monitoring Results Average Day (MGD) | Report Table 4-5 Projected Wet Weather Peak Day (MGD) | BKF Model Projected Wet Weather Peak Day (MGD) |
|---|---|---|---|---|--|
| Basin 3 | | | 1.72 | 4.07 | 4.07 |
| Basin 4 | | | 1.91 | 5.94 | 5.94 |
| Basin 5 | | | 3.9 | 8.67 | 8.67 |
| Moffett Meter | 0.113 | 0.096 | 0.097 | 4.22 | 0.45 |
| Subtotal | | | 7.63 | 22.9 | 19.13 |
| Palo Alto Treatment Plant Meter | | | 7.43 | 19.54 | 19.54 |
| Difference at Plant Meter | | | 0.20 3% | 3.36 17% | -0.41 -2% |

CONCLUSION: Existing Average Daily Flow to Moffett Meter = 0.1 MGD

Monitoring Results - Meter S101 at N-255

| | | |
|-------------------------------|-------------|-------------|
| August, 1998 | 3,220,140 | gallons |
| September, 1998 | 3,686,892 | gallons |
| Total | 6,907,032 | gallons |
| Days | 61 | |
| | 113230.0328 | gallons/day |
| Average metered use, 1998 | 0.113 | mgd |
| Moffet Meter 1990 (Table 4-2) | 0.097 | |
| <hr/> | | |
| Difference | 0.016 | |
| | 17% | |
| | | |
| May, 1999 | 2,533,476 | |
| June, 1999 | 3,322,616 | |
| Total | 5,856,092 | gallons |
| Days | 61 | |
| | 96,002 | gallons/day |
| Average metered use, 1999 | 0.096 | mgd |
| Moffet Meter 1990 (Table 4-2) | 0.097 | |
| <hr/> | | |
| Difference | -0.001 | |
| | -1% | |

Note: Meter readings during wet months are suspect because the City shuts off a downstream pump station. When this occurs, there is a tailwater on the meter station that affects the meter results.

A P P E N D I X C 5

S T O R M D R A I N D I S C H A R G E



NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 5
STORM DRAIN ANALYSIS
TABLE 5.1
STORM DRAIN DISCHARGE

| Drainage Area | Acres | C-Factor | I - 10yr (inch/hour) | Q - 10yr (cfs) | I - 25yr (inch/hour) | Q - 25yr (cfs) | I - 100yr (inch/hour) | Q - 100yr (cfs) |
|----------------------|--------------|-----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|----------------------------------|----------------------------|
| 1 | 150 | 0.86 | 0.71 | 92 | 0.8 | 103 | 0.95 | 123 |
| 2 | 320 | 0.86 | 0.71 | 195 | 0.8 | 220 | 0.95 | 261 |
| Hwy 101 R/W | 35 | 0.90 | 0.71 | 22 | 0.8 | 25 | 0.95 | 30 |
| 3 | 100 | 0.86 | 0.71 | 61 | 0.8 | 69 | 0.95 | 82 |
| 4 | 50 | 0.86 | 0.71 | 31 | 0.8 | 34 | 0.95 | 41 |
| 5 | 30 | 0.86 | 0.71 | 18 | 0.8 | 21 | 0.95 | 25 |
| 6 | 930 | 0.65 | 0.71 | 429 | 0.8 | 484 | 0.95 | 574 |
| Hwy 101 R/W | 15 | 0.90 | 0.71 | 10 | 0.8 | 11 | 0.95 | 13 |

Note: This table contains only calculations for total discharge from each drainage area.

A P P E N D I X C 6

NATURAL GAS DEMAND



**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 6
GAS ANALYSIS
ANNUAL GAS DEMAND SUMMARY**

Summary of Existing and Proposed Gas Demand

Existing and proposed demands for the various alternates are based on the calculations shown on the spreadsheets on the following pages.

| Development Alternate | Annual Gas Demand (Kilo Therms) |
|-----------------------|---------------------------------|
| Existing | 4064 |
| 1- Baseline | 4,330 |
| 2 | 7,130 |
| 3 | 6,508 |
| 4 | 7,854 |
| 5 - Preferred | 6,939 |

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 6
GAS ANALYSIS
TABLE 6.0
EXISTING NATURAL GAS DEMAND

| TABLE 6.0 | | Unit Gas Demand (KThrms/sf) | Annual Gas Demand (KThrms) |
|--|--------------|--------------------------------------|-------------------------------------|
| Development Area \ Description | Area | | |
| NASA RESEARCH PARK | | | |
| Existing Buildings | 1,187,269 sf | 0.00065 | 772 |
| Hangar 1 - Existing Use | 390,000 sf | 0.00030 | 117 |
| Subtotal - NRP | 1,577,269 sf | | 889 |
| EAST SIDE/AIRFIELD | | | |
| Existing Buildings | 79,023 sf | 0.00065 | 51 |
| Hangars 2 & 3 - Existing Use | 780,613 sf | 0.00030 | 234 |
| Subtotal - Eastside/Airfield | 859,636 sf | | 286 |
| AMES CAMPUS | | | |
| Existing Buildings | 2,889,658 sf | 0.00100 | 2,890 |
| Subtotal - AMES CAMPUS | 2,889,658 sf | | 2,890 |
| Total - NASA Ames Research Center | | | 4,064 |

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 6
GAS ANALYSIS**

**TABLE 6.1
NATURAL GAS DEMAND - ALTERNATE 1**

| TABLE 6.1 | | Unit Gas Demand (KThrms/sf) | Annual Gas Demand (KThrms) |
|--|--------------|--------------------------------------|-------------------------------------|
| Development Area \ Description | Area | | |
| LAB | | | |
| Office/High Density R&D | 590,000 sf | 0.00067 | 395 |
| Computer Lab | 100,000 sf | 0.00067 | 67 |
| Auditorium | 30,000 sf | 0.00080 | 24 |
| Subtotal - Lab | 720,000 sf | | 486 |
| NASA RESEARCH PARK | | | |
| Existing Buildings | 739,962 sf | 0.00065 | 481 |
| Hangar 1 - Existing Use | 390,000 sf | 0.00030 | 117 |
| Invisible Studios | 105,000 sf | 0.00067 | 70 |
| Subtotal - NRP | 1,234,962 sf | | 668 |
| Subtotal - Lab and NRP | 1,954,962 sf | | 1,155 |
| EAST SIDE/AIRFIELD | | | |
| Existing Buildings | 79,023 sf | 0.00065 | 51 |
| Hangars 2 & 3 - Existing Use | 780,613 sf | 0.00030 | 234 |
| Subtotal - Eastside/Airfield | 859,636 sf | | 286 |
| AMES CAMPUS | | | |
| Existing Buildings | 2,889,658 sf | 0.00100 | 2,890 |
| Subtotal - AMES CAMPUS | 2,889,658 sf | | 2,890 |
| Total - NASA Ames Research Center | | | 4,330 |

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 6
GAS ANALYSIS
TABLE 6.2
NATURAL GAS DEMAND - ALTERNATE 2

| TABLE 6.2 | | Unit Gas Demand (KThrms/sf) | Annual Gas Demand (KThrms) |
|--|--------------|--------------------------------------|-------------------------------------|
| Development Area \ Description | Area | | |
| LAB | | | |
| Office/High Density R&D | 590,000 sf | 0.00067 | 395 |
| Computer Lab | 100,000 sf | 0.00067 | 67 |
| Auditorium | 30,000 sf | 0.00080 | 24 |
| Subtotal - Lab | 720,000 sf | | 486 |
| NASA RESEARCH PARK | | | |
| Existing Buildings | 112,990 sf | 0.00065 | 73 |
| Invisible Studios | 105,000 sf | 0.00067 | 70 |
| Office/High Density R&D | | | |
| Historic Infill | 100,000 sf | 0.00067 | 67 |
| Space Camp | 140,000 sf | 0.00067 | 94 |
| Gateway Parcels | 262,010 sf | 0.00067 | 176 |
| University Office | 352,800 sf | 0.00070 | 247 |
| University Classroom | 487,200 sf | 0.00070 | 341 |
| Museum (Computer) | 70,000 sf | 0.00080 | 56 |
| Museum (CASC) | 390,000 sf | 0.00080 | 312 |
| Conference Center | 200,000 sf | 0.00080 | 160 |
| Part Time Housing (1 unit/800 sf) | 150,000 sf | 0.00080 | 120 |
| Family Housing (1 unit/1,200 sf) | 360,000 sf | 0.00086 | 310 |
| Retail (University) | 50,000 sf | 0.00100 | 50 |
| Subtotal - NRP | 2,780,000 sf | | 2,076 |
| Subtotal - Lab and NRP | 3,500,000 sf | | 2,562 |
| BAY VIEW | | | |
| Office/High Density R&D | 500,000 sf | 0.00067 | 335 |
| University Office | 210,000 sf | 0.00067 | 141 |
| University Classroom | 290,000 sf | 0.00067 | 194 |
| Family Housing (1 unit/1,200 sf) | 300,000 sf | 0.00086 | 258 |
| Subtotal - Bay View | 300,000 sf | | 928 |
| EAST SIDE/AIRFIELD | | | |
| Existing Buildings | 79,023 sf | 0.00065 | 51 |
| Hangars 2 & 3 | 780,613 sf | 0.00041 | 320 |
| Office / R&D / Industrial | 470,000 sf | 0.00067 | 315 |
| Conference Center | 80,000 sf | 0.00080 | 64 |
| Subtotal - Eastside/Airfield | 1,409,636 sf | | 750 |
| AMES CAMPUS | | | |
| Existing Buildings | 2,889,658 sf | 0.00100 | 2,890 |
| Subtotal - AMES CAMPUS | 2,889,658 sf | | 2,890 |
| Total - NASA Ames Research Center | | | 7,130 |

NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 6
GAS ANALYSIS

TABLE 6.3
NATURAL GAS DEMAND - ALTERNATE 3

| TABLE 6.3 | | Unit Gas Demand (KThrms/sf) | Annual Gas Demand (KThrms) |
|--|--------------|--------------------------------------|-------------------------------------|
| Development Area \ Description | Area | | |
| LAB | | | |
| Office/High Density R&D | 590,000 sf | 0.00067 | 395 |
| Computer Lab | 100,000 sf | 0.00067 | 67 |
| Auditorium | 30,000 sf | 0.00080 | 24 |
| Subtotal - Lab | 720,000 sf | | 486 |
| NASA RESEARCH PARK | | | |
| Existing Buildings | 112,990 sf | 0.00065 | 73 |
| Invisible Studios | 105,000 sf | 0.00067 | 70 |
| Office/High Density R&D | | | |
| Historic Infill | 115,000 sf | 0.00067 | 77 |
| Space Camp | 200,000 sf | 0.00067 | 134 |
| Gateway Parcels | 362,010 sf | 0.00067 | 243 |
| Parcel 9 / Others | 750,000 sf | 0.00067 | 503 |
| University Office | 352,800 sf | 0.00070 | 247 |
| University Classroom | 487,200 sf | 0.00070 | 341 |
| Museum (Computer) | 70,000 sf | 0.00080 | 56 |
| Museum (CASC) | 390,000 sf | 0.00080 | 312 |
| Conference Center | 250,000 sf | 0.00080 | 200 |
| Part Time Housing (1 unit/800 sf) | 150,000 sf | 0.00080 | 120 |
| Family Housing (1 unit/1,200 sf) | 360,000 sf | 0.00086 | 310 |
| Retail (University) | 75,000 sf | 0.00100 | 75 |
| Subtotal - NRP | 3,780,000 sf | | 2,760 |
| Subtotal - Lab and NRP | 4,500,000 sf | | 3,247 |
| EAST SIDE/AIRFIELD | | | |
| Existing Buildings | 79,023 sf | 0.00065 | 51 |
| Hangars 2 & 3 | 780,613 sf | 0.00041 | 320 |
| Subtotal - Eastside/Airfield | 859,636 sf | | 371 |
| AMES CAMPUS | | | |
| Existing Buildings | 2,889,658 sf | 0.00100 | 2,890 |
| Subtotal - AMES CAMPUS | 2,889,658 sf | | 2,890 |
| Total - NASA Ames Research Center | | | 6,508 |

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 6
GAS ANALYSIS**

**TABLE 6.4
NATURAL GAS DEMAND - ALTERNATE 4**

| TABLE 6.4 | | Unit Gas Demand (KThrms/sf) | Annual Gas Demand (KThrms) |
|--|--------------|--------------------------------------|-------------------------------------|
| Development Area \ Description | Area | | |
| LAB | | | |
| Office/High Density R&D | 590,000 sf | 0.00067 | 395 |
| Computer Lab | 100,000 sf | 0.00067 | 67 |
| Auditorium | 30,000 sf | 0.00080 | 24 |
| Subtotal - Lab | 720,000 sf | | 486 |
| NASA RESEARCH PARK | | | |
| Existing Buildings | 112,990 sf | 0.00073 | 82 |
| Invisible Studios | 105,000 sf | 0.00067 | 70 |
| Office/High Density R&D | | | |
| Historic Infill | 50,000 sf | 0.00067 | 34 |
| Space Camp | 55,000 sf | 0.00067 | 37 |
| Gateway Parcels | 97,010 sf | 0.00067 | 65 |
| University Office | 336,000 sf | 0.00070 | 235 |
| University Classroom | 464,000 sf | 0.00070 | 325 |
| Museum (Computer) | 70,000 sf | 0.00080 | 56 |
| Museum (CASC) | 390,000 sf | 0.00080 | 312 |
| Conference Center | 185,000 sf | 0.00080 | 148 |
| Part Time Housing (1 unit/800 sf) | 115,000 sf | 0.00080 | 92 |
| Family Housing (1 unit/1,200 sf) | 265,000 sf | 0.00086 | 228 |
| Retail (University) | 35,000 sf | 0.00100 | 35 |
| Subtotal - NRP | 2,280,000 sf | | 1,719 |
| Subtotal - Lab and NRP | 3,000,000 sf | | 2,205 |
| BAY VIEW | | | |
| Office/High Density R&D | 1,540,000 sf | 0.00067 | 1,032 |
| University Office | 126,000 sf | 0.00067 | 84 |
| University Classroom | 174,000 sf | 0.00067 | 117 |
| Low Density R&D / Industrial | 200,000 sf | 0.00064 | 128 |
| Family Housing (1 unit/1,200 sf) | 660,000 sf | 0.00086 | 568 |
| Subtotal - Bay View | 2,700,000 sf | | 1,928 |
| EAST SIDE/AIRFIELD | | | |
| Existing Buildings | 79,023 sf | 0.00065 | 51 |
| Hangars 2 & 3 | 780,613 sf | 0.00041 | 320 |
| Office / R&D / Industrial | 590,000 sf | 0.00067 | 395 |
| Conference Center | 80,000 sf | 0.00080 | 64 |
| Subtotal - Eastside/Airfield | 1,529,636 sf | | 831 |
| AMES CAMPUS | | | |
| Existing Buildings | 2,889,658 sf | 0.001 | 2,890 |
| Subtotal - AMES CAMPUS | 2,889,658 sf | | 2,890 |
| Total - NASA Ames Research Center | | | 7,854 |

**NASA AMES DEVELOPMENT PLAN - EIS
APPENDIX C: INFRASTRUCTURE - SECTION 6
GAS ANALYSIS**

**TABLE 6.5
NATURAL GAS DEMAND - ALTERNATE 5**

| TABLE 6.5 | | Unit Gas Demand (KThrms/sf) | Annual Gas Demand (KThrms) |
|--|--------------|--------------------------------------|-------------------------------------|
| Development Area \ Description | Area | | |
| LAB | | | |
| Office/High Density R&D | 590,000 sf | 0.00067 | 395 |
| Computer Lab | 100,000 sf | 0.00067 | 67 |
| Auditorium | 30,000 sf | 0.00080 | 24 |
| Subtotal - Lab | 720,000 sf | | 486 |
| NASA RESEARCH PARK | | | |
| Existing Buildings | 54,355 sf | 0.00065 | 35 |
| Invisible Studios | 105,000 sf | 0.00067 | 70 |
| Office/High Density R&D | | | |
| Historic Infill | 155,000 sf | 0.00067 | 104 |
| Space Camp | 70,000 sf | 0.00067 | 47 |
| Parcel 9 / Others | 223,645 sf | 0.00067 | 150 |
| University Office | 406,560 sf | 0.00070 | 285 |
| University Classroom | 561,440 sf | 0.00070 | 393 |
| Museum (Computer) | 120,000 sf | 0.00080 | 96 |
| Museum (CASC) | 500,000 sf | 0.00080 | 400 |
| Conference Center | 250,000 sf | 0.00080 | 200 |
| Recreation (Conference Center) | 25,000 sf | 0.00080 | 20 |
| Part Time Housing (1 unit/800 sf) | 232,000 sf | 0.00080 | 186 |
| Retail (University) | 50,000 sf | 0.00100 | 50 |
| Retail (Gateway & Historic Infill) | 27,000 sf | 0.00100 | 27 |
| Subtotal - NRP | 2,780,000 sf | | 2,062 |
| Subtotal - Lab and NRP | 3,500,000 sf | | 2,549 |
| BAY VIEW | | | |
| Child Care | 25,000 sf | 0.00095 | 24 |
| Retail | 75,000 sf | 0.00100 | 75 |
| Family Housing (1 unit/1,200 sf) | 900,000 sf | 0.00086 | 774 |
| Subtotal - Bay View | 1,000,000 sf | | 873 |
| EAST SIDE/AIRFIELD | | | |
| Existing Buildings | 79,023 sf | 0.00065 | 51 |
| Hangars 2 & 3 - Existing Use | 780,613 sf | 0.00030 | 234 |
| Low Density R&D / Industrial | 12,000 sf | 0.00064 | 8 |
| Subtotal - Eastside/Airfield | 871,636 sf | | 293 |
| AMES CAMPUS | | | |
| Existing Buildings | 2,889,658 sf | 0.00100 | 2,890 |
| Office/High Density R&D | 500,000 sf | 0.00067 | 335 |
| Subtotal - AMES CAMPUS | 3,389,658 sf | | 3,225 |
| Total - NASA Ames Research Center | | | 6,939 |