

NASA Lyndon B Johnson Space Center, Houston, TX - TX1010250 - UCMR 5 Results

Analyte	01/27/2025 (SE1)	04/14/2025 (SE2)	07/28/2025 (SE3)	10/20/2025 (SE4)	01/06/2026 (SE4-Resample)
	Analyte Results (µg/l or micrograms per liter)				
4:2 FTS	< MRL	< MRL	< MRL	< MRL	N/A
6:2 FTS	< MRL	< MRL	< MRL	< MRL	N/A
8:2 FTS	< MRL	< MRL	< MRL	< MRL	N/A
9Cl-PF3ONS	< MRL	< MRL	< MRL	< MRL	N/A
11Cl-PF3OUdS	< MRL	< MRL	< MRL	< MRL	N/A
ADONA	< MRL	< MRL	< MRL	< MRL	N/A
HFPO-DA	< MRL	< MRL	< MRL	< MRL	N/A
lithium	< MRL	< MRL	< MRL	< MRL	N/A
NEtFOSAA	< MRL	< MRL	< MRL	*LE	< MRL
NFDHA	< MRL	< MRL	< MRL	< MRL	N/A
NMeFOSAA	< MRL	< MRL	< MRL	*LE	< MRL
PFBA	0.0060	0.0058	< MRL	0.0059	N/A
PFBS	< MRL	< MRL	< MRL	< MRL	N/A
PFDA	< MRL	< MRL	< MRL	< MRL	N/A
PFDoA	< MRL	< MRL	< MRL	< MRL	N/A
PFEESA	< MRL	< MRL	< MRL	< MRL	N/A
PFHpA	< MRL	< MRL	< MRL	< MRL	N/A
PFHpS	< MRL	< MRL	< MRL	< MRL	N/A
PFHxA	0.0045	0.0038	< MRL	< MRL	N/A
PFHxS	< MRL	< MRL	< MRL	< MRL	N/A
PFMBA	< MRL	< MRL	< MRL	< MRL	N/A
PFMPA	< MRL	< MRL	< MRL	< MRL	N/A
PFNA	< MRL	< MRL	< MRL	< MRL	N/A
PFOA	< MRL	< MRL	< MRL	< MRL	N/A
PFOS	< MRL	< MRL	< MRL	< MRL	N/A
PFPeA	0.0053	0.0040	< MRL	< MRL	N/A
PFPeS	< MRL	< MRL	< MRL	< MRL	N/A
PFTA	< MRL	< MRL	< MRL	*LE	< MRL
PFTTrDA	< MRL	< MRL	< MRL	*LE	< MRL
PFUnA	< MRL	< MRL	< MRL	< MRL	N/A

MRL - "Minimum Reporting Level" is the lowest detectable amount using the EPA's test method.

SE - "Sample Event"

*LE - "Lab Error" indicates results that had issues during the lab analysis, which triggered the resample on 01/06/2026.

N/A - "Not Applicable" indicates results that were not sampled for in the resample analysis on 01/06/2026 sampling event since the results were available from the previous SE4.