FREEZE PLAN TASK LIST
WATER & WASTEWATER SHOP

TASK	LOCATION	FREEZE PLAN IMPLEMENTED (DATE/INITIAL)	SYSTEM RESTORED (DATE/INITIAL)
VERIFY THAT THE SIGHT GLASS IS VALVED OUT AND DRAINED, SURGE TANK AT 5TH STREET NORTH SIDE IN HMF AREA.	HMF		
VERIFY THAT THE SIGHT GLASS IS VALVED OUT AND DRAINED, SURGE TANK AT M7-1104 (MPPF)	HMF		
VERIFY THAT THE SIGHT GLASS IS VALVED OUT AND DRAINED, SURGE TANK AT ISTEF/TEL-4 FACILITY.	TEL-4		
SET UP FREEZE PROTECTION (DRIP & TAG) OF BACKFLOW PREVENTER ON NE CORNER OF M7-1104	M7-1104		
CLOSE PRESSURE GAUGE PG-8 ISOLATION VALVE AND BLEED PRESSURE FROM GAUGE.	RPSF		
CLOSE PUMP ROOM VENTILATION DOORS BEHIND EACH FIREX DIESEL.	UTILITY ANNEX		
SLIGHTLY OPEN HOSEBIBBS ON OUTSIDE OF FACILITIES LOCATED AT THE SRB/ARF COMPLEX.	BFF FACILITY/AFT SKIRT TEST BLDG		
SET UP FREEZE PROTECTION (DRIP & TAG) ON THE SAFETY SHOWER AT M6-0584, BEHIND M&O FACILITY.	INDUSTRIAL AREA		
USE THE PORTABLE BFP LIST TO SET UP FREEZE PROTECTION (DRIP & TAG) ON UNPROTECTED BFP'S.	KSC		
OPEN ALL OF THE POTABLE WATER SAMPLE POINT HOSE BIBBS TO A SLOW TRICKLE.	KSC		
OPEN HOSEBIBB ON LOOP AROUND O&C FACILITY.	INDUSTRIAL AREA		
OPEN HOSEBIBB BEHIND M6-0698.	INDUSTRIAL AREA		
LEVEL TRANSMITTER RPT-1, NORTHSIDE RESERVOIR, COVER.	PAD PUMP STATION		
RW-65 (AND PIPE), STEEL RESERVOIR FILL VALVE, COVER.	PAD PUMP STATION		
RW-101 (AND PIPE), CONCRETE RESERVOIR FILL VALVE, COVER.	PAD PUMP STATION		
LEVEL TRANSMITTER RPT-110, NORTHSIDE RESERVOIR, COVER.	PAD PUMP STATION		
COVER CLA-VAL RW-127 TEST VALVE TRIM	PAD PUMP STATION		
PRESSURE TRANSMITTER PT-1, POTABLE WATER LINE, COVER.	PAD PUMP STATION		
HOSE CONNECTIONS, PAD SURFACE: REMOVE CAPS AND ALLOW TRICKLE FLOW.	PAD B		

FREEZE PLAN TASK LIST
WATER & WASTEWATER SHOP

PAD SURFACE: SAFETY SHOWERS PARTIALLY OPEN ISOLATION VALVE TO ALLOW TRICKLE FLOW TO DRAIN.	PAD B		
DRAIN TANK T4A SIGHT GAGE	PAD B TANK FARM		
COVER POTABLE WATER PRESSURE SENSOR LINES IN TANK FARM	PAD B TANK FARM		
SAFETY SHOWER/EYEWASH UNITS, PAD PERIMETER: OPEN VALVE TO ALLOW TRICKLE FLOW THROUGH UNITS.	PAD B		
HOSEBIBS, HOSEREELS, PAD PERIMETER: OPEN VALVE TO ALLOW TRICKLE FLOW.	PAD B		
COVER TRIM ON SMALL CLA-VALS NEAR WEST HOLDING POND	PAD B		
COVER 1” BYPASS LINE FOR V-280 ON EAST PAD SLOPE	PAD B		
COVER W-5 FILL VALVE TRIM	W-5 PUMP STATION		
DRAIN W-5 HYDROPNUEMATIC TANK SIGHT GLASS	W-5 PUMP STATION		
NOTIFY DUTY OFFICE OF STATUS.			